


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1200LOCATION PS150 MDATE 4/15/06PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
South Side		70.0	59.0	480	2	24	0
SE Corner		70.1	58.7	478	2	24	0
East Side		70.3	58.2	477	2	25	0
NE Corner		69.9	57.9	475	2	28	0
North Side		69.7	57.5	481	2	26	0
NW Corner		70.0	57.0	485	2	21	0
West side		69.8	57.3	490	2	20	0
North (Top of stairs)		70.4	58.0	480	2	23	0
East (Top of stairs)		70.6	58.2	476	2	20	0
Main Entrance		70.9	58.2	468	2	19	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working in the CourtyardThe assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/15/06

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759565

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1230LOCATION PS150 MDATE 4/15/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Lobby		72.5	54.8	561	2	28	0
Main Foyer		71.5	55.5	528	2	24	0
Hall by West Stairs		70.6	56.5	507	2	26	0
Main Desk		71.1	55.3	544	2	21	0
Ed's Room	7	71.7	57.9	634	2	18	0
Main Office	3	72.1	57.3	584	2	20	0
Guidance Rm	5	71.8	57.7	606	2	23	0
Hall by Girls Rm		72.0	57.6	569	2	22	0
Hall by boys Rm		72.2	57.7	571	2	20	0
Hall by East Stairs		72.5	52.5	572	2	21	0
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 4/15/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759566

ATC ASSOCIATES, INC.

Page 3 of 4

TIME 1300

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 MDATE 4/15/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Resource Rm		74.1	55.6	620	2	19	0
Nurse Rm		73.1	55.0	618	2	18	0
Kitchen		74.3	56.1	629	2	20	0
Music Rm		73.3	55.6	622	2	21	0
Hall by Step Sink		73.2	55.1	630	2	20	0
404	20	75.1	54.4	790	2	18	0
H03		75.0	54.5	764	2	16	0
H03 (Hall)		75.0	53.5	600	2	22	0
Hall by Boys Rm		75.1	53.6	596	2	20	0
Hall by Girls Rm		75.3	53.5	540	2	21	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 4/15/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,


CITY_21MC100_005759567

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 4/15/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by Staff Rm		74.5	55.2	570	2	13	0
402	20	74.9	54.1	809	2	30	0
401	18	75.0	54.0	610	2	19	0
501		73.8	53.8	709	2	18	0
Hall by West Stairs		74.2	56.0	574	2	20	0
502		74.0	53.6	622	2	12	0
503	10	73.6	54.1	639	2	24	0
504		73.9	53.8	640	2	19	0
504 (H1711)		74.0	56.3	578	2	19	0
Hall by Staircase		74.3	56.0	580	2	20	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/15/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759568