

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 1 of 4TIME 1200LOCATION PS150 MDATE 4/18/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
South Side		83.0	47.3	470	3	30	0
SE Corner		83.3	47.0	473	3	32	0
East Side		83.6	47.2	479	3	34	0
NE Corner		83.8	47.4	481	3	30	0
North Side		84.0	47.8	480	3	28	0
NW Corner		83.6	47.6	485	3	30	0
West Side		83.8	48.0	490	3	34	0
North Top of Stairs		84.0	48.1	489	3	30	0
Main Entrance		84.2	48.4	491	3	28	0
East Top of Stairs		84.4	48.8	495	3	30	0
Guideline levels ASHRAE/ATIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 4/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759592

ATC ASSOCIATES, INC.

Page 2 of 4

INDOOR AIR QUALITY FIELD REPORT

TIME 1230LOCATION PS150 MDATE 4/18/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Lobby		73.1	45.4	790	3	29	0
Ed's Rm.	10	72.8	45.0	801	3	19	0
Main Desk		72.6	45.3	788	3	26	0
Main Office	2	73.0	45.6	810	3	30	0
Guidance Rm		72.6	45.9	890	3	32	0
Hall by Boys		73.3	46.3	781	3	30	0
Hall by Girls		73.5	46.5	777	3	28	0
Hall by East Stair		73.8	46.7	786	3	30	0
Resource Rm	3	73.6	46.9	819	3	26	0
Nurse Rm	1	74.0	50.0	830	3	16	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 4/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759593

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1300LOCATION PS150 MDATE 4/18/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Kitchen		74.0	46.8	709	3	20	0
Music Rm		73.8	47.0	800	3	28	0
Hall by Slop Sink		74.3	47.3	719	3	30	0
Hall by West stair		74.5	47.8	723	3	32	0
Main Foyer.		74.7	48.0	720	3	36	0
401		73.6	46.3	739	3	29	0
402		73.0	45.1	744	3	26	0
Hall by Staff Rm		73.6	47.0	729	3	30	0
Hall by Boys		73.8	47.3	727	3	32	0
Hall by Girls		74.0	47.5	730	3	30	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jing Chen Date: 4/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759594

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 4/18/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
403		72.9	47.0	711	3	20	0
404		73.3	47.3	715	3	18	0
404 (Hall)		73.9	48.0	699	3	26	0
Hall by East Stairs		74.1	48.3	690	3	28	0
504		73.0	46.0	717	3	21	0
503		73.6	45.8	737	3	24	0
503 (Hall)		74.3	48.0	688	3	28	0
502		73.9	48.6	727	3	20	0
501		74.0	48.1	738	3	18	0
501 (Hall)		74.4	47.6	700	3	26	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jin Chen Date: 4/18/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759595