

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

LOCATION PS 150 N DATE 4-25-02 PROJECT NO. 19125-289

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>200</u>	<u>OUTSIDE</u>						
<u>0</u>	<u>SOUTH</u>	<u>53.2</u>	<u>33.8</u>	<u>509</u>	<u>2</u>	<u>20</u>	<u>0</u>
<u>0</u>	<u>SOUTHEAST CORNER</u>	<u>53.4</u>	<u>33.8</u>	<u>477</u>	<u>2</u>	<u>21</u>	<u>0</u>
<u>0</u>	<u>EAST SIDE</u>	<u>53.2</u>	<u>34.6</u>	<u>446</u>	<u>2</u>	<u>19</u>	<u>0</u>
<u>0</u>	<u>NORTHEAST CORNER</u>	<u>53.4</u>	<u>34.9</u>	<u>452</u>	<u>2</u>	<u>19</u>	<u>0</u>
<u>0</u>	<u>EAST TOP OF STAIRS</u>	<u>53.4</u>	<u>34.6</u>	<u>486</u>	<u>2</u>	<u>19</u>	<u>0</u>
<u>0</u>	<u>NORTH</u>	<u>53.4</u>	<u>34.6</u>	<u>499</u>	<u>2</u>	<u>19</u>	<u>0</u>
<u>0</u>	<u>NORTHWEST CORNER</u>	<u>53.4</u>	<u>34.6</u>	<u>526</u>	<u>2</u>	<u>18</u>	<u>0</u>
<u>0</u>	<u>WEST SIDE</u>	<u>53.4</u>	<u>33.9</u>	<u>510</u>	<u>2</u>	<u>17</u>	<u>0</u>
<u>2</u>	<u>MAIN ENTRANCE</u>	<u>53.2</u>	<u>35.6</u>	<u>459</u>	<u>2</u>	<u>21</u>	<u>0</u>
<u>0</u>	<u>NEXT TO TOP OF STAIRS</u>	<u>53.2</u>	<u>35.7</u>	<u>501</u>	<u>2</u>	<u>21</u>	<u>0</u>
	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	~~50~~ ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 4-25-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759636

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

LOCATION PS 150 W DATE 4-25-02 PROJECT NO. 14125-289

occup

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
2	MAIN FOYER	72.1	34.6	668	2	20	0
2	MAIN DESK	71.9	34.6	659	2	21	0
0	NEXT TO WEST STAIRS HALL	72.1	34.7	446	2	21	0
2	MAIN LOBBY	71.6	34.7	641	2	19	0
0	EDS ROOM	72.2	35.1	501	2	21	0
1	MAN OFFICE	72.9	35.6	601	2	21	0
0	GUIDANCE ROOM	72.6	35.7	591	2	21	0
0	NEXT TO BOYS ROOM HALL	71.9	35.1	592	2	21	0
0	NEXT TO GIRLS ROOM HALL	71.8	34.9	593	2	20	0
0	NEXT TO EAST STAIRS HALL	71.9	34.6	577	2	19	0
0	Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	~~20~~ 19 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4 - - 02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759637

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3LOCATION PS 150 mDATE 4-25-02PROJECT NO. 19125 - 287

occup

2

1

3

0

0

16

10

0

0

0

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource Rm	72.6	34.6	616	2	19	0
Nurse Rm	72.9	34.7	599	2	19	0
Kitchen	72.9	35.1	603	2	19	0
Music Rm	72.9	35.1	489	2	18	0
Next to Shop Sink	72.3	35.6	481	2	22	0
404	72.1	35.7	589	2	19	0
403	71.9	34.1	810	2	19	0
403 Hall	71.9	34.6	461	2	18	0
Next to Boys Rm	71.6	34.7	477	2	21	0
Next to Girls Rm	71.3	35.6	489	2	21	0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	~~20~~ ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 4-25-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759638

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4

LOCATION PS 150 M DATE 4-25-02 PROJECT NO. 14125-289

	Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
ccup ✓	HALL BY STAFF	71.2	34.5	510	2	19	C
0	402	70.6	34.6	499	2	19	C
0	401	70.3	34.7	486	2	18	C
5	HALL BY WEST STAIRS	70.6	34.6	702	2	20	C
2	501	71.1	35.5	669	2	20	C
15	502	70.4	34.0	891	2	20	C
23	503	70.6	34.6	929	2	20	C
15	504	70.9	34.1	959	2	20	C
0	504 HALL	71.3	33.9	456	2	20	C
0	HALL BY EAST STAIRS	70.9	33.6	481	2	20	C
	Guideline levels ASHRAE/AIHA	69-76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	~~50~~ ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

4-25-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759639