

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1TIME 1200LOCATION PS150 M DATE 4/8/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
South Side		51.1	44.0	440	1	2	0.0
SE Corner		50.8	44.3	444	1	2	0.0
East Side		50.5	44.5	448	1	2	0.0
NE Corner		50.1	45.0	452	1	2	0.0
North Side		49.9	45.5	455	1	2	0.0
NW Corner		49.6	45.8	460	1	2	0.0
West Side		49.3	46.3	463	1	2	0.0
Top Floor (North)		49.0	46.8	467	1	2	0.0
Main Entrance		48.8	47.3	471	1	2	0.0
Top Floor (East)		48.6	47.7	476	1	3	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working in courtyard

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4/8/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759654

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1230LOCATION P5150 MDATE 4/24/06PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Entry		71.1	43.7	820	0	6	0.0
2nd Floor Lobby		71.2	43.9	829	0	4	0.0
Main Desk		71.3	42.3	840	0	6	0.0
2nd Floor Corridor		70.6	41.0	698	0	4	0.0
Main Lobby		70.5	40.5	706	0	7	0.0
Main Corridor		71.1	40.7	692	0	2	0.0
2nd Floor Rm		71.1	40.0	693	0	4	0.0
2nd Floor Corridor		71.9	40.6	766	0	6	0.0
2nd Floor Corridor		72.0	40.9	777	0	7	0.0
2nd Floor Corridor		72.2	41.1	777	0	5	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 4/24/06

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759655

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 11

TIME 1200

LOCATION PS150 M

DATE 4/24/08

PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Resource Rm	2	72.5	38.0	613	0	5	0.0
Nurse Rm	1	73.0	38.0	726	0	11	0.0
Kitchen	2	73.6	38.0	796	0	10	0.0
Wash Sink	1	73.8	39.0	842	0	12	0.0
Music Rm	18	73.2	39.0	911	0	20	0.0
HCH	20	73.4	38.2	922	0	8	0.0
HCH (Hall)		74.1	38.0	820	0	6	0.0
HCH	14	73.6	36.3	870	0	5	0.0
Boy Rm (Hall)		73.5	35.1	720	0	8	0.0
Girls Rm (Hall)		73.7	35.8	720	0	7	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 4/24/08

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL

CITY_21MC100_005759656

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 4/24/08PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
501 (Hallway)		73.4	34.7	670	0	5	0.0
402	9	72.0	39.2	640	0	5	0.0
401	1	72.3	35.0	629	0	6	0.0
500 (Staircase)	-	72.3	34.0	650	0	5	0.0
501	22	71.5	36.3	879	0	9	0.0
502	18	71.9	35.9	817	0	10	0.0
(Hall) 503 Rm		71.8	37.6	920	0	10	0.0
503	30	72.0	36.9	1010	0	8	0.0
505 (Hall)		72.2	40.6	909	0	17	0.0
504	18	72.3	37.3	840	0	10	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 4/24/08

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759657