

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1200LOCATION PS150 MDATE 5/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
West Side		60.0	31.5	485	1	33	0.0
NW Corner		59.8	31.7	480	1	30	0.0
North		59.5	31.9	486	1	25	0.0
NE Corner		59.2	32.3	490	1	23	0.0
East Side		58.8	32.5	494	1	24	0.0
~~NE~~ SE Corner		58.5	32.8	501	1	28	0.0
South		58.1	33.1	496	1	26	0.0
North (Top Stairs)		57.9	33.0	503	1	25	0.0
Main Entrance		57.7	32.9	500	1	23	0.0
East Side		58.0	32.8	508	1	20	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 5/1/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759672

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1230LOCATION PS150 MDATE 5/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		68.6	38.8	680	0	15	0.0
Hall West Stairs		68.8	38.6	677	0	14	0.0
Main Deck		69.4	38.1	712	0	16	0.0
ED'S Room	6	70.0	38.3	711	0	12	0.0
Main Lobby		70.3	37.8	718	0	15	0.0
Main Office		71.0	36.8	720	0	10	0.0
Guidance Rm	4	70.8	35.8	700	0	15	0.0
Hall by Girls Rm		70.8	35.0	685	0	15	0.0
Hall by Boys Rm		70.9	34.9	680	0	15	0.0
Hall East Stairs		70.9	35.0	677	0	15	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/1/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759673

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1300LOCATION PS150 MDATE 5/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource Rm		72.8	34.6	905	0	20	0.0
Nurse Rm	2	73.4	34.9	911	0	15	0.0
Kitchen	2	75.0	36.6	930	0	28	0.0
Music Rm	23	74.3	35.0	974	0	21	0.0
Hall Slop Sink		72.7	36.6	920	0	15	0.0
404	18	74.8	36.2	1002	0	12	0.0
403 (Hall)		74.4	32.4	782	0	12	0.0
Boys Rm (Hall)		74.4	31.9	748	0	17	0.0
Girls Rm (Hall)		74.5	31.8	744	0	15	0.0
Staff Rm (Hall)		74.3	31.8	751	0	18	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: 403 Test

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 5/1/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759674

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 5/1/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
402	18	73.0	30.1	901	0	13	0.0
401	20	72.9	31.4	790	0	17	0.0
West Stair (Hall)		73.2	31.4	765	0	18	0.0
501	21	72.1	33.1	1053	0	20	0.0
502	2	72.0	31.0	740	0	17	0.0
Staff Rm (Hall)		72.1	32.1	1046	0	20	0.0
Girls Rm (Hall)		72.4	32.3	1048	0	19	0.0
Boys Rm (Hall)		72.4	32.6	1055	0	20	0.0
503	31	72.6	32.6	1144	0	16	0.0
504	21	73.0	34.3	1218	0	20	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 5/1/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759675