

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1

TIME 0900

LOCATION PS150M DATE 5/15/08 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside							
1st Fl		68.4	42.2	385	1	1.1	0.1
2nd Fl		68.4	42.0	384	1	1.1	0.1
3rd Fl		68.8	41.8	387	1	1.1	0.1
4th Fl		68.2	41.6	382	1	1.1	0.1
5th Fl		68.5	41.3	385	1	1.1	0.1
6th Fl		68.7	41.1	382	1	1.1	0.1
West		68.0	40.9	381	1	1.1	0.1
North Wing		68.2	40.2	388	1	1.1	0.1
Main Entrance		68.0	40.3	382	1	1.1	0.1
East (T-1)		68.8	41.5	387	1	1.1	0.1
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working on the building

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/15/08

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759762

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1230LOCATION PS150MDATE 5/15/02 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
1st Floor		67.4	52.0	614	1	10	0.1
2nd Floor		67.5	52.0	611	1	10	0.1
3rd Floor		67.2	51.1	603	1	10	0.1
4th Floor	4	67.5	51.1	612	1	10	0.1
5th Floor	5	67.6	52.2	611	1	10	0.1
6th Floor	2	67.7	52.2	616	1	10	0.1
7th Floor	5	67.7	52.0	612	1	10	0.1
8th Floor		67.7	52.0	630	1	10	0.1
9th Floor		67.6	52.0	632	1	10	0.1
10th Floor (Garage)		67.5	52.0	618	1	10	0.1
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 5/15/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759763

ATC ASSOCIATES, INC.

Page 3 of 5

INDOOR AIR QUALITY FIELD REPORT

TIME 1300LOCATION PS150MDATE 5/15/08 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
1st Floor (1st floor)		65.8	41.2	122	1	12	1.1
2nd Floor	1	65.9	34.2	130	1	17	2.1
3rd Floor	1	71.0	45.8	211	1	1	1.1
4th Floor (1st floor)		61.3	33.1	100	1	5	1.1
5th Floor	21	71.4	50.5	500	1	12	1.1
6th Floor		71.1	30.9	620	1	11	1.1
7th Floor (1st floor)		70.5	30.0	600	1	15	1.1
8th Floor (1st floor)		70.8	30.1	616	1	14	1.1
9th Floor (1st floor)		70.6	30.0	623	1	10	1.1
10th Floor (1st floor)		70.6	30.1	650	1	17	1.1
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: 1st floor, 2nd floor, 3rd floor, 4th floor, 5th floor, 6th floor, 7th floor, 8th floor, 9th floor, 10th floorThe assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 5/15/08

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759764

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 44 of 44TIME 1:30LOCATION PS150M DATE 5/15/02 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
1st Flr. (entr)		70.0	30.0	600	1	14	0.0
2nd Flr.	10	69.0	30.0	650	1	13	0.0
3rd Flr.	15	70.0	30.0	700	1	14	0.0
West St. (entr)		70.0	30.0	700	1	14	0.0
4th Flr.	15	69.0	30.0	700	1	14	0.0
5th Flr.	10	69.0	30.0	700	1	14	0.0
West St. (entr)		69.0	30.0	650	1	14	0.0
6th Flr.	17	69.0	30.0	700	1	17	0.0
East St. (entr)		69.0	30.0	670	1	17	0.0
7th Flr.	1	69.0	30.0	700	1	14	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 5/15/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759765