

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1200LOCATION PS150 MDATE 5/16/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
South		73.1	23.8	400	2	2	...
SE		72.8	24.0	398	2	20	...
East		73.2	24.2	396	2	18	...
NE		73.6	24.5	390	2	19	...
North		73.9	24.7	388	2	22	...
Mid		74.1	24.9	390	2	20	...
West		74.3	25.1	396	2	18	...
North (top)		74.4	25.3	399	2	20	...
Main Entrance		74.6	25.7	401	2	19	...
East (top)		74.4	26.0	395	2	16	...
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Greg Chen Date: 5/16/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759771

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1230LOCATION PS150MDATE 5/16/02PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Entry		74.2	31.0	578	1	13	C.C.
West Entry		74.2	31.1	676	1	14	C.C.
Main Desk		74.0	31.0	570	1	13	C.C.
Main Lobby		74.2	30.9	600	1	15	C.C.
EL's Room		72.7	31.6	613	1	28	C.C.
Man Office	2	73.0	32.8	664	1	11	C.C.
Principal Office		73.3	33.3	742	1	12	C.C.
Guidance Room	3	73.1	32.7	699	1	18	C.C.
Circle Room (main)		73.6	32.3	575	1	20	C.C.
Boys Room (main)		73.8	32.2	590	1	23	C.C.
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 5/16/02

CITY_21MC100_005759772

CONFIDENTIAL,

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1300LOCATION PS150M DATE 5/16/02 PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
East St.		74.2	32.4	600	2	25	0.1
Reception Rm	2	74.2	33.0	721	2	20	0.1
News Rm	2	74.5	33.4	789	2	25	0.1
Video Room		75.1	34.0	817	2	20	0.1
Storage Room (main)		75.4	35.1	1130	2	20	0.1
Photo Rm		75.3	35.0	1090	2	15	0.1
Lab 4	2	75.4	34.9	543	2	20	0.1
Lab 3		74.8	33.0	629	2	25	0.1
Reception (lower)		75.1	32.2	600	2	24	0.1
Guidance (main)		75.2	32.0	544	2	23	0.1
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/16/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759773

ATC ASSOCIATES, INC.

Page 5 of 4

INDOOR AIR QUALITY FIELD REPORT

TIME 1330LOCATION PS150MDATE 5/16/02PROJECT NO. 19125-0289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
402		74.5	31.0	578	2	14	0.00
West stair		74.8	32.5	651	2	25	0.00
401	22	74.6	33.4	1034	2	28	0.00
501		72.9	31.8	573	2	24	0.00
502		73.1	31.6	520	2	20	0.00
CHFF Rm (400)		74.0	31.5	514	2	20	0.00
Boys Rm (400)		74.1	31.6	516	2	21	0.00
Girls Rm (400)		74.3	31.5	513	2	20	0.00
503		73.0	31.0	576	2	19	0.00
504		73.5	31.4	535	2	18	0.00
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Sign [illegible] Date: 5/16/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759774