

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

Time: 05 pm LOCATION: P-150 DATE: 6/12/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
OUTSIDE							
SOUTH SIDE	10	87.1	52.4	560	1	86	0
SOUT EAST CORNER	0	87.1	52.2	561	1	90	0
EAST SIDE	9	87.1	52.1	560	1	91	0
NORTHEAST CORNER	0	87.2	52.1	559	1	90	0
EAST TOP OF STAIRS	16	87.0	52.1	546	1	88	0
NORTHWEST CORNER	0	87.9	52.1	555	1	90	0
WEST SIDE	10	87.9	52.1	560	1	89	0
MAIN ENTRANCE	1	87.6	52.1	561	1	91	0
NEXT TO TOP OF STAIRS	3	88.0	52.1	559	1	83	0
NORTH SIDE	1	88.4	52.1	559	1	85	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *[Signature]* Date: 6/12/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759933

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

Time: 1:30 pm LOCATION: PS 15C DATE: 6/12/02 PROJECT NO: 19125-0287

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
MAIN REYER	2	78.9	55.7	589	1	55	0
MAIN RESE	1	78.6	55.4	561	1	56	0
NEXT TO WEST STAIRS HALL	1	79.1	54.7	567	1	41	0
MAIN LOBBY	3	79.3	54.6	619	1	50	0
EXS ROOM	1	76.1	49.1	601	1	28	0
MAIN OFFICE	3	72.3	48.1	636	1	31	0
EVIDENCE ROOM	0	74.1	47.3	599	1	19	0
NEXT TO BOYS FULL HALL	0	78.6	55.6	577	1	25	0
NEXT TO GIRLS FULL HALL	0	79.1	55.9	589	1	32	0
NEXT TO EAST STAIRS HALL	0	79.3	55.9	601	1	36	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 6/12/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759934

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 3 of 4

Time: 2:00 pm

LOCATION: PS 150

DATE: 6/12/02 PROJECT NO: 19125-0287

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hallway NEXT TO STAFF RM	0	78.9	55.6	616	1	28	0
402	15	74.6	47.8	891	1	31	0
401	22	74.3	48.6	1039	1	26	0
Hall BY WEST STAIRS	0	78.6	55.3	589	1	22	0
501	25	74.1	46.1	1136	1	28	0
502	22	74.3	47.1	1026	1	33	0
503	1	73.9	46.6	710	1	31	0
504	20	78.7	42.5	1362	1	31	0
504 HALLWAY	0	79.1	54.1	606	1	31	0
Hall BY EAST STAIRS	0	79.0	54.6	610	1	31	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/12/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MCI00_005759935

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 10

Time: 2:26 PM LOCATION: PS 150

DATE: 6/12/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource Room	0	75.9	49.6	589	1	22	0
Nurse Room	1	75.7	49.1	601	1	19	0
Kitchen	3	76.3	50.1	619	1	26	0
Music Room	1	75.1	56.1	556	1	18	0
Next to Slop Sink	0	78.9	54.1	603	1	21	0
404	25	74.6	49.1	1133	1	21	0
403 Hallway	0	78.9	47.6	558	1	16	0
Out Doors 403 Classroom	22	74.1	47.1	1081	1	24	0
Out Doors Next to Boys Rm	0	78.8	56.6	610	1	28	0
Out Doors Next to Girls Room	0	78.9	56.6	626	1	25	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/12/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_005759936