


05/07/2002 11:41 1000000001

EPA 301-10001

**EMSL Analytical, Inc.**

107 Haddon Ave., Westmont, NJ 08108

Phone: (856) 858-4800 Fax: (856) 858-4960 Email: ssiegel@EMSL.com

Attn: Terry Smith
U. S. EPA
HQ Financial Services Division
1200 Pennsylvania Ave. NW Maildrop 2734R
Washington, DC 20460

Customer ID: USEPA30
Customer PO: 2W-1104-NNLX
Received: 05/06/02 10:00 AM

Fax: Phone: 703-603-8849
Project:

EMSL Order: 040206055
EMSL Project ID:
Analysis Date 5/7/02

**Asbestos Analysis of Non-Friable Organically Bound materials by Transmission
Electron Microscopy via NYS ELAP Method 198.4**

SAMPLE ID	DESCRIPTION	APPEARANCE	% MATRIX MATERIAL	% NON- ASBESTOS	ASBESTOS TYPES	% TOTAL ASBESTOS
IAQ-B-2A-001 040206055-0005		Gray Non-Fibrous Homogeneous	100.0	None	<1 Chrysotile	<1
IAQ-B-2A-002 040206055-0006		Gray Non-Fibrous Homogeneous	100.0	None	<1 Chrysotile	<1
IAQ-B-2B-001 040206055-0007		Gray Non-Fibrous Homogeneous	100.0	None	<1 Chrysotile	<1
IAQ-B-5C-001 040206055-0008		Gray Non-Fibrous Homogeneous	100.0	None	<1 Chrysotile	<1

Marques Stanard

Analyst

Stephen Siegel, CIH
or other approved signatory

This laboratory is not responsible for % asbestos in total sample when the residue only is submitted for analysis. This above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc.

ACCREDITATIONS: AIHA #100192, NVLAP #101048-0 and NY STATE ELAP #10872

NYC-NOR-2

1