NYC 9/11 Public Portal Document

KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

CHAIN OF CUSTOD[Y] FOR ASBESTOS AIR MONITORING

CLIENT: DCAS
PROJECT: CITY HALL
SAMPLING DATE: 08-14-01 FRI
ADDRESS: DOWNTOWN MANHATTAN, NY

FIELD DATA										LAB ANALYSIS			
SAMPLE ID#	TYPE	LOCATION	RESP	WORK	TIME IN	TIME OUT	FLOW BEF. (lpm)	FLOW AFTER (lpm)	VOLUME (liters)	FIBERS PER FIELD	FIBERS PER CC	LAB ID # A0109[illegible]B	CASSETTE 25MM 37MM
1	L	CITY HALL BASEMENT AND 3RD FLOOR LOCKER ROOM BETWEEN 2ND/3RD FLOOR N/E			7[illegible]	10[illegible]	10	10	1800	3.5/100	<0.01	1	TEST METHOD: (PCM) TEM
2	L	3RD FLOOR ART COMMISSION OFFICE NORTH			7[illegible]	10[illegible]	10	10	1850	5/100	<0.01	2	
3	L	3RD FLOOR ART COMMISSION CORRIDOR NORTH SIDE			7[illegible]	10[illegible]	10	10	1850	7.5/100	<0.01	3	TURN-AROUND TIME:
4	L	" WEST SIDE			7[illegible]	10[illegible]	10	10	1800	9/100	<0.01	4	IMMEDIATE
5	L	" SOUTH SIDE			7[illegible]	10[illegible]	10	10	1800	2/100	<0.01	5	12-HOUR
6	L	" EAST SIDE			7[illegible]	10[illegible]	10	10	1800	2/100	<0.01	6	24-HOUR
7	L	3RD FLOOR ART COMMISSION SOUTH/WEST OFFICE			7[illegible]	10[illegible]	10	10	1850	13.5/100	<0.01	7	24-HOUR
8	L	3RD FLOOR ART COMMISSION SOUTH CONFERENCE ROOM			7[illegible]	10[illegible]	10	10	1800	10/100	<0.01	8	OTHER:
9	L	OUTSIDE BLDG. SOUTH SIDE			7[illegible]	10[illegible]	10	10	1800	5/100	<0.01	9	ANALYST: DB
10	L	BASEMENT ROOM 1A S/W			9[illegible]	11[illegible]	10	10	1200	2/100	<0.01	10	
11	L	BASEMENT - EAST ROOM WEST AXIS SPIRAL STAIRS N/W			9[illegible]	11[illegible]	10	10	1200	4/100	<0.01	11	DATE OF ANALYSIS: 9-15-01
12	K	FIELD BLANK								0/100	—	12	
13	K	"								0/100	—	13	TIME OF ANALYSIS:

SAMPLE TYPE: A=BACKGROUND, B=PREABATEMENT, C=DURING ABATEMENT, D=POST-ABATEMENT
E=OUTSIDE WORK AREA, F=INSIDE WORK AREA, G=MICROTRAP EXHAUST DISCHARGE
H=DECONTAMINATION FACILITY, I=CRITICAL BARRIER, J=OUTSIDE BLDG, K=FIELD BLANK
L=AIR QUALITY, M=COMPLIANCE MONITORING

TYPE OF RESPIRATORS: 1 = HALF FACE, 2 = PAPR, 3 = TYPE C, 4 = OTHER (SPECIFY):

TYPE OF WORK: 1= BLDG DECON, 2 = PLASTICIZING, 3 = GROSS REMOVAL, 4 = GLOVEBAG, 5 = CLEANING, 6 = ENCAPSULATION, 7 = BAGOUT, 8 = OTHER (SPECIFY):

TECHNICIAN: DB. NOWAK
ROTAMETER: KAM - 04
PAGE 1 OF 1

CHAIN OF CUSTODY	RELINQUISHED BY:	METHOD OF SHIPMENT:	DATE/TIME:	COMMENTS:	RECEIVED AT LAB BY: DB	SAMPLE CONDITION UPON RECEIPT: good	DATE/TIME: 9-15-01

RECEIVED
KAM CONSULTANTS
2001 SEP 15 AM 10

CITY_21MC100_011837445

NYC-WTC_000178173