

60 LAFAYETTE STREET



KAM CONSULTANTS
 35-40 36th Street
 Long Island City
 New York, 11106
 Tel: (718) 729-1997
 Fax: (718) 729-1876

REPORT OF AIR MONITORING

(PHASE CONTRAST MICROSCOPY ANALYSIS OF AIR FILTERS)

CLIENT: DCAS

DATE: 09/27/01

PROJECT:

ADDRESS: 60 Laffayette Street, Manhattan

19th Floor

CLIENT SAMPLE ID#	LOCATION	R E S P	W O R K	TIME IN	TIME OUT	FLOW BEF. (lpm)	FLOW AFTER (lpm)	SAMPLE VOLUME (liters)	FIBERS PER FIELD	FIBERS PER CC	REMARKS	LAB ID#
01	11th Floor - Room 11A	1		15:30	17:30	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-01
02	11th Floor - Stair Y & Lobby	1		15:31	17:31	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-02
03	11th Floor - Stair Z			15:32	17:32	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-03
04	9th Floor - By Courtrooms Part 6 & 7			15:45	17:45	10	10	1200	0.060	<0.01	Air Quality (Immed. TAT)	A010928F-04
05	9th Floor - By Legal A/D Society			15:46	17:46	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-05
06	9th Floor - Stairs Y & Lobby			15:47	17:47	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-06
07	9th Floor - Stairs Z			15:48	17:48	10	10	1200	0.090	<0.01	Air Quality (Immed. TAT)	A010928F-07
08	9th Floor - By Room 9D			15:49	17:49	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-08
09	7th Floor - Waiting Area 7D			16:05	18:05	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-09
10	7th Floor - Waiting Area 7C			16:07	18:07	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-10
11	7th Floor - Stairs 7Y & Lobby			16:09	18:09	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-11
12	7th Floor - Waiting Area 7A			16:10	18:10	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-12
13	7th Floor - Waiting Area 7B			16:11	18:11	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-13
14	By Courtroom Part 5			16:30	18:30	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-14
15	Waiting Room By 5F			16:31	18:31	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-15
16	By Stairs Z - Lobby			16:33	18:33	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-16
17	by Stairs Y - Lobby			16:35	18:35	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-17
18	Waiting Room by Legal Aid			16:36	18:36	10	10	1200	0.060	<0.01	Air Quality (Immed. TAT)	A010928F-18
19	1st Floor - By Main Entrance Laffayette Street			16:56	18:56	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-19
20	1st Floor - Elevator Lobby Stairs Y			16:57	18:57	10	10	1200	0.070	<0.01	Air Quality (Immed. TAT)	A010928F-20
21	1st Floor - Elevator Lobby Stairs Z			16:58	18:58	10	10	1200	0.100	<0.01	Air Quality (Immed. TAT)	A010928F-21
22	1st Floor - Waiting Room Probation			16:59	18:59	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-22
23	Level "A" - In the Pautry			17:30	19:30	10	10	1200	<0.055	<0.01	Air Quality (Immed. TAT)	A010928F-23

TYPE OF RESPIRATORS:

TYPE OF WORK:

1 = HALF FACE, 2 = PAPR, 3 = TYPE C, 4 = OTHER (SPECIFY):

1= BLDG DECON, 2 = PLASTICIZING, 3 = GROSS REMOVAL, 4 = GLOVEBAG, 5 = CLEANING,

6 = ENCAPSULATION, 7 = BAGOUT, 8 = OTHER (SPECIFY):

SAMPLING TECHNICIAN: M. Golembo, M. Tchatchueng, Z.B. Now: DATE RECEIVED: 09/28/01

ROTAMETER: KAM- 04

DATE OF ANALYSIS: 09/28/01

DATE OF REPORT: 09/28/01

Analyst:

Deepak Bajracharya

Lab Manager:

David Chen

The samples listed above are analyzed by Phase Contrast Microscopy (PCM) as per NIOSH 7400 Method -Issue 3. The detection limit of this method is 7 fibers per square mm per filter area.

KAM CONSULTANTS shall not be liable for information arising from samples that are not in its QA and QC program.

The results relate only to the items calibrated or tested. The certificate of report shall not be reproduced without approval of the laboratory.

The report must not be used by the client to claim endorsement by NVLAP or any agency of the U.S. Government.

NYS-DOH ELAP # 11273

AIHA # 100269



KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

REPORT OF AIR MONITORING

(PHASE CONTRAST MICROSCOPY ANALYSIS OF AIR FILTERS)

CLIENT: DCAS.
PROJECT:
19th Floor

DATE: 09/27/01
ADDRESS: 60 Laffayette Street, Manhattan

[illegible]

TYPE OF RESPIRATORS:
TYPE OF WORK:

1 = HALF FACE, 2 = PAPR, 3 = TYPE C, 4 = OTHER (SPECIFY):

1= BLDG DECON, 2 = PLASTICIZING, 3 = GROSS REMOVAL, 4 = GLOVEBAG, 5 = CLEANING, 6 = ENCAPSULATION, 7 = BAGOUT, 8 = OTHER (SPECIFY):

SAMPLING TECHNICIAN: M. Golembo, M. Tchatchueng, Z.B. Nowinski
ROTAMETER: KAM- 04

DATE RECEIVED: 09/28/01

DATE OF ANALYSIS: 09/28/01

DATE OF REPORT: 09/28/01

Analyst:

Deepak Bairacharya

Lab Manager:

David Chen

The samples listed above are analyzed by Phase Contrast Microscopy (PCM) as per NIOSH 7400 Method -Issue 3. The detection limit of this method is 7 fibers per square mm per filter area. KAM CONSULTANTS shall not be liable for information arising from samples that are not in its QA and QC program.

The results relate only to the items calibrated or tested. The certificate of report shall not be reproduced without approval of the laboratory.

The report must not be used by the client to claim endorsement by NVLAP or any agency of the U.S. Government.

NYS-DOH ELAP # 11273

AIHA # 100269



KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

CHAIN OF CUSTODY FOR ASBESTOS AIR MONITORING

CLIENT: DCAS
PROJECT:

SAMPLING DATE: 60 LAFAYETTE ST
ADDRESS: MTTALL
08-27-01 THU

FIELD DATA										LAB ANALYSIS			
SAMPLE ID#	TYPE	LOCATION	R E S P	W O R K	TIME IN pm	TIME OUT pm	FLOW BEF. (lpm)	FLOW AFTER (lpm)	VOLUME (liters)	FIBERS PER FIELD	FIBERS PER CC	LAB ID #	CASSETTE 25MM 37MM
1	L	11 TH FLOOR			3 ³⁰	5 ³⁰	10	10	1200	2	<0.01	A010928F	
2	L	ROOM 11A			3 ³¹	5 ³¹	10	10	1200	0.5	<0.01	1	TEST METHOD: PCM TEM
3	L	STAIR Y & LOBBY			3 ³²	5 ³²	10	10	1200	1	<0.01	2	TURN-AROUND TIME: IMMEDIATE
4	L	STAIR Z										3	12-HOUR
5	L	9 TH FLOOR										4	24-HOUR
6	L	BY COURT ROOMS BRT			3 ⁴⁵	5 ⁴⁵	10	10	1200	6	<0.01	5	24-HOUR
7	L	BY LEGAL AID SOCIETY			3 ⁴⁶	5 ⁴⁶	10	10	1200	4	<0.01	6	OTHER:
8	L	STAIRS Y & LOBBY			3 ⁴⁷	5 ⁴⁷	10	10	1200	1	<0.01	7	ANALYST: DB
9	L	STAIR Z			3 ⁴⁸	5 ⁴⁸	10	10	1200	9	<0.01	8	DATE OF ANALYSIS: 9-28-01
10	L	BY ROOM 9D			3 ⁴⁸	5 ⁴⁸	10	10	1200	3	<0.01	9	TIME OF ANALYSIS: 3:31
11	L	7 TH FLOOR										10	
12	L	WAITING AREA 7D			4 ⁰⁵	6 ⁰⁵	10	10	1200	5	<0.01	11	
13	L	11-7C			4 ⁰⁷	6 ⁰⁷	10	10	1200	4	<0.01	12	
14	L	STAIRS 7Y and LOBBY			4 ⁰⁸	6 ⁰⁸	10	10	1200	1.5	<0.01		
15	L	WAITING AREA 7A			4 ¹⁰	6 ¹⁰	10	10	1200	3	<0.01		

SAMPLE TYPE:

A=BACKGROUND, B=PREABATEMENT, C=DURING ABATEMENT, D=POST-ABATEMENT
E=OUTSIDE WORK AREA, F=INSIDE WORK AREA, G=MICROTRAP EXHAUST DISCHARGE
H=DECONTAMINATION FACILITY, I=CRITICAL BARRIER, J=OUTSIDE BLDG, K=FIELD BLANK
L= AIR QUALITY, M=COMPLIANCE MONITORING

TYPE OF RESPIRATORS:

TYPE OF WORK:

1 = HALF FACE, 2 = PAPR, 3 = TYPE C, 4 = OTHER (SPECIFY):

1 = BLDG DECON, 2 = PLASTICIZING, 3 = GROSS REMOVAL, 4 = GLOVEBAG, 5 = CLEANING,
6 = ENCAPSULATION, 7 = BAGOUT, 8 = OTHER (SPECIFY):

TECHNICIAN: MICHAEL MATIEU, ZBIGNIEW

ROTAMETER: KALL-04

PAGE 1 OF 3

CHAIN OF CUSTODY	RELINQUISHED BY:	COMMENTS:	RECEIVED AT LAB BY: <u>DB</u>
DATE/TIME:	METHOD OF SHIPMENT:		SAMPLE CONDITION UPON RECEIPT: <u>Good</u>



KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

CHAIN OF CUSTODY FOR ASBESTOS AIR MONITORING

CLIENT: DCAS
PROJECT:

SAMPLING DATE: 09-27-01 THU
ADDRESS: 60 LAFAYETTE ST
MT-TTAC, NY

FIELD DATA										LAB ANALYSIS			
SAMPLE ID#	TYPE	LOCATION	R E S P	W O R K	TIME IN PLN	TIME OUT	FLOW BEF. (lpm)	FLOW AFTER (lpm)	VOLUME (liters)	FIBERS PER FIELD	FIBERS PER CC	LAB ID #	CASSETTE 25MM 37MM
13	L	7th floor WAITING AREA 7B			4:11	6:11	10	10	1200	1/100	100	A010928 F	13
14	L	BY COURT ROOM PART 5			4:20	6:30	10	10	1200	0.5/100	100		14
15	L	WAITING ROOM 5F			4:31	6:31	10	10	1200	1/100	100		15
16	L	BY STAIRS 2 LOBBY			4:33	6:33	10	10	1200	1/100	100		16
17	L	11-Y LOBBY			4:35	6:35	10	10	1200	2/100	100		17
18	L	WAITING ROOM BY LEGAL AID			4:36	6:36	10	10	1200	6/100	100		18
19	L	1st floor BY MAIN ELEVATOR			4:56	6:56	10	10	1200	3/100	100		19
20	L	ELEVATOR STAIRS 4 LOBBY			4:57	6:57	10	10	1200	7/100	100		20
21	L	11-STAIRS 2			4:58	6:58	10	10	1200	10/100	100		21
22	L	WAITING ROOM PROBATION			4:58	6:58	10	10	1200	3/100	100		22
23	L	LEVEL "A" IN THE RALLY			5:30	7:30	10	10	1200	4/100	100		23

SAMPLE TYPE:

A=BACKGROUND, B=PREABATEMENT, C=DURING ABATEMENT, D=POST-ABATEMENT
E=OUTSIDE WORK AREA, F=INSIDE WORK AREA, G=MICROTRAP EXHAUST DISCHARGE
H=DECONTAMINATION FACILITY, I=CRITICAL BARRIER, J=OUTSIDE BLDG, K=FIELD BLANK
L= AIR QUALITY, M=COMPLIANCE MONITORING

TYPE OF RESPIRATORS:

1 = HALF FACE, 2 = PAPR, 3 = TYPE C, 4 = OTHER (SPECIFY):

TYPE OF WORK:

1= BLDG DECON, 2 = PLASTICIZING, 3 = GROSS REMOVAL, 4 = GLOVEBAG, 5 = CLEANING,
6 = ENCAPSULATION, 7 = BAGOUT, 8 = OTHER (SPECIFY):

TECHNICIAN: MICHAEL MATTHEW ZBIGNIEW

ROTAMETER: KALU-04

PAGE 2 OF 3

CHAIN OF CUSTODY	RELINQUISHED BY:	COMMENTS:	RECEIVED AT LAB BY: <u>DB</u>
	METHOD OF SHIPMENT:		SAMPLE CONDITION UPON RECEIPT: <u>Good</u>
	DATE/TIME:		DATE/TIME:

CITY_21MC100_011837600

RECEIVED
KAM CONSULTANTS
2001 SEP 28 AM 5:31



KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

CHAIN OF CUSTODY FOR ASBESTOS AIR MONITORING

CLIENT: DCAS
PROJECT:

SAMPLING DATE: 09-27-01 THU
ADDRESS:

60-LAFAYETTE ST
MT-TOWN, NY

FIELD DATA										LAB ANALYSIS			
SAMPLE ID#	TYPE	LOCATION	R E S P	W O R K	TIME IN PM	TIME OUT PM	FLOW BEF. (lpm)	FLOW AFTER (lpm)	VOLUME (liters)	FIBERS PER FIELD	FIBERS PER CC	LAB ID #	CASSETTE 25MM 37MM
24	L	LEVEL "A" LOBBY STAIR Y			5:32	7:32	10	10	1200	6	100	24	TEST METHOD: PCM TEM
25	L	LOBBY ROOM HIEHS			5:34	7:34	10	10	1200	6	100	25	TURN-AROUND TIME: IMMEDIATE
26	L	ELEVATOR LOBBY			5:35	7:35	10	10	1200	2	100	26	12-HOUR
27	L	LOBBY ROOM HIEHS			5:37	7:37	10	10	1200	2	100	27	24-HOUR
28	K	FIELD BLANK								0	100	28	24-HOUR
29	K	IL								0	100	29	OTHER:
30	K	IL								0	100	30	ANALYST: DB
													DATE OF ANALYSIS: 9-28-01
													TIME OF ANALYSIS:

SAMPLE TYPE:

A=BACKGROUND, B=PREABATEMENT, C=DURING ABATEMENT, D=POST-ABATEMENT
E=OUTSIDE WORK AREA, F=INSIDE WORK AREA, G=MICROTRAP EXHAUST DISCHARGE
H=DECONTAMINATION FACILITY, I=CRITICAL BARRIER, J=OUTSIDE BLDG, K=FIELD BLANK
L= AIR QUALITY, M=COMPLIANCE MONITORING

TYPE OF RESPIRATORS:

TYPE OF WORK:

1 = HALF FACE, 2 = PAPR, 3 = TYPE C, 4 = OTHER (SPECIFY):
1 = BLDG DECON, 2 = PLASTICIZING, 3 = GROSS REMOVAL, 4 = GLOVEBAG, 5 = CLEANING,
6 = ENCAPSULATION, 7 = BAGOUT, 8 = OTHER (SPECIFY):

TECHNICIAN: MICHAEL, MATIEU, ZBIGNIEW

ROTAMETER: KAM-04

15 SEP 28 AM 5:31
KAM CONSULTANTS
PAGE 1

CHAIN OF CUSTODY	RELINQUISHED BY: METHOD OF SHIPMENT: DATE/TIME:	COMMENTS:	RECEIVED AT LAB BY: <u>DB</u> SAMPLE CONDITION UPON RECEIPT: <u>good</u> DATE/TIME:
------------------	---	-----------	---