

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 05-13-02

CLIENT: NYC BOE

PROJECT ADDRESS: P.S. 89M/201 Warren St.
NY, NY 10282

PROJECT NO: 41617-0562
SAMPLED BY: M. Nakhumovich

SAMPLE DATE: 05-10-02
DATE RECEIVED: 05-10-02
DATE ANALYZED: 05-10-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft ²)	DETECTION LIMIT (µg/ft ²)
01	9808	Outside of School Ground Concr. Surface North Side Enter.	14.8	9.0
02	9808	Outside of School Ground Concr. Surface South Side Enter.	<9.0	9.0
03	9808	Playground Gournd Concr. Surface Center	<9.0	9.0
04	9808	Playground Gournd Concr. Surface South Side	11.9	9.0
05	9808	Playground Gournd Concr. Surface North Side	14.6	9.0
06	9808	Playground Gournd Concr. Surface East Side	15.6	9.0
07	9808	Playground Gournd Concr. Surface West Side	13.8	9.0
08	9808	Cafeteria Floor	12.9	9.0
09	9808	1st Floor Hallway Floor South of Cafeteria	18.7	9.0
10	9808	1st Floor Hallway Floor East of Cafeteria	13.6	9.0
11	9808	2nd Floor Hallway Floor South Side	14.8	9.0
12	9808	Auditorium Floor	<9.0	9.0
13	9808	Gymnasium Floor	12.4	9.0
14	9808	Rm 304 Floor East Side Unit Vent	15.2	9.0
15	9808	Rm 502 Window Sill South Side Unit Vent	3.0	2.4

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

16	9808	Rm 426 Floor North Side Unit Vent	17.3	9.0
17	9808	4th Floor Hallway Floor South Side	14.9	9.0
18	9808	Rm 201 Floor	15.4	9.0
19	9808	Rm 202 Floor	17.1	9.0
20	9808	Rm 204 Floor	14.2	9.0
21	9808	Rm 226 Floor	18.2	9.0
22	9808	Rm 230 Floor	15.4	9.0
23	9808	Rm 232 Floor	20.7	9.0
24	9808	Rm 219 Floor	18.1	9.0
25	9808	Rm 228 Floor	16.8	9.0
26	9808	Rm 302 Floor	20.4	9.0
27	9808	Rm 301 Floor	17.3	9.0
28	9808	Rm 319 Floor	22.9	9.0
29	9808	Rm 316 Floor	23.1	9.0
30	9808	Rm 326 Floor	23.3	9.0
31	9808	Rm 401 Floor	<9.0	9.0
32	9808	Rm 402 Floor	<9.0	9.0
33	9808	Rm 408 Floor	<9.0	9.0
34	9808	Rm 426 Floor	<9.0	9.0
35	9808	Rm 428 Floor	<9.0	9.0
36	9808	Rm 506 Floor	<9.0	9.0
37	9808	Rm 512 Floor	<9.0	9.0
38	9808	Rm 526 Floor	<9.0	9.0
39	9808	Rm 528 Floor	<9.0	9.0
40	9808	Rm 532 Floor	<9.0	9.0
41	9808	Blank	<9.0 µg	9.0 µg
42	9808	Blank	<9.0 µg	9.0 µg
43	9808	Blank	<9.0 µg	9.0 µg
44	9808	Blank	<9.0 µg	9.0 µg