


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4TIME 1200LOCATION PS150 M DATE 4/11/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside							
West Side		58.1	31.3	468	1	32	0
NW Corner		58.3	31.0	472	1	27	0
North Side		58.7	30.8	475	1	32	0
NE Corner		59.0	30.6	479	1	30	0
East Side		59.3	30.3	474	1	31	0
SE Corner		59.5	30.0	470	1	29	0
South Side		60.0	30.3	466	1	28	0
North Top of Stair		59.8	30.5	460	1	31	0
East Top of Stair		59.6	30.9	465	1	30	0
Main Entrance		59.9	31.0	471	1	31	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: Working in the CourtyardThe assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 4/11/02


CITY_21MC100_002893874

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1230LOCATION PS150 M DATE _____ PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		68.0	39.3	667	667 1	20	0
Hall by West Stair		67.8	38.9	661	661 1	22	0
Main Deck		68.9	39.7	736	1	22	0
Ed's Rm.		69.3	39.3	704	1	17	0
Main Lobby		70.0	39.1	747	1	20	0
Main Office		70.4	39.5	818	1	13	0
Guidance Rm	5	70.7	37.8	754	1	17	0
Hall by Girls Rm		71.1	37.1	724	1	21	0
Hall by boys Rm		71.2	37.3	739	1	24	0
Hall by East Stairs		71.4	36.1	683	1	24	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 7/11/02

CITY_21MC100_002893875

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4


TIME 1300

LOCATION PS150 M DATE 4/11/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Stairs		71.8	35.6	710	1	23	0
Reception Rm	2	72.1	34.8	742	1	19	0
Nurse Rm	1	72.5	34.5	755	1	12	0
Kitchen	1	73.4	34.1	888	1	20	0
Music Rm	20	73.1	34.6	861	1	27	0
East Stairs	-	74.4	31.9	558	1	22	0
404	25	75.2	33.5	860	1	16	0
404 (Hall)		75.3	33.0	871	1	21	0
403	23	74.4	33.1	962	1	25	0
Hall by Stairs		75.2	31.1	719	1	24	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/11/02

CITY_21MC100_002893876

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4


TIME 1330

LOCATION PS150 M DATE 4/11/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Boy Rm		75.4	30.4	635	2	27	0
Hall by Staff Rm		75.3	29.6	648	2	22	0
402	9	73.4	28.0	713	2	15	0
Hall by West Stairs		74.3	24.2	644	2	22	0
401	30	73.9	24.4	1006	2	19	0
501	3	73.4	31.0	684	2	16	0
502	19	72.0	27.2	970	2	16	0
Hall by Rest Rm		73.0	30.5	726	2	24	0
503	19	73.8	32.7	1120	2	22	0
504	20	74.0	32.3	906	2	25	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 4/11/02