

**ATC ASSOCIATES, INC.**  
**INDOOR AIR QUALITY FIELD REPORT**

Page 1 of 4

TIME 1200

LOCATION PS150 M DATE 5/10/02 PROJECT NO. 19125-289

| Location                                   | Occup. | Temperature (°F)                   | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m³) | TVOCs (ppm) |
|--------------------------------------------|--------|------------------------------------|-----------------------|----------------------------|-----------------------|---------------------------------|-------------|
| Outside                                    |        |                                    |                       |                            |                       |                                 |             |
| Th                                         |        | 69.2                               | 37.5                  | 600                        | 0                     | 23                              | 0.0         |
| NE                                         |        | 69.4                               | 37.3                  | 600                        | 0                     | 24                              | 0.0         |
| East                                       |        | 69.7                               | 37.6                  | 600                        | 0                     | 25                              | 0.0         |
| N                                          |        | 70.0                               | 37.4                  | 600                        | 0                     | 22                              | 0.0         |
| NW                                         |        | 69.6                               | 37.2                  | 599                        | 0                     | 25                              | 0.0         |
| West                                       |        | 69.1                               | 37.0                  | 596                        | 0                     | 23                              | 0.0         |
| West                                       |        | 69.5                               | 37.6                  | 590                        | 0                     | 25                              | 0.0         |
| Hallway                                    |        | 69.9                               | 37.3                  | 585                        | 0                     | 24                              | 0.0         |
| Main Entrance                              |        | 70.0                               | 37.5                  | 591                        | 0                     | 25                              | 0.0         |
| East                                       |        | 70.3                               | 37.8                  | 580                        | 0                     | 23                              | 0.0         |
| <b>Guideline levels</b><br>ASHRAE/AIHA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m³<br>24-hour average     | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: \_\_\_\_\_ Date: 5/10/02

**ATC ASSOCIATES, INC.**  
**INDOOR AIR QUALITY FIELD REPORT**

Page 2 of 4

TIME 2:30

LOCATION PS150 M DATE 5/10/02 PROJECT NO. 19125-289

| Location                                    | Occup. | Temperature (°F)                 | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|---------------------------------------------|--------|----------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| Vis. Elev.                                  |        | 71.9                             | 41.8                  | 650                        | 0                     | 23                                           | 0.0         |
| West Elev.                                  |        | 72.0                             | 41.6                  | 653                        | 0                     | 25                                           | 0.0         |
| Main Elev.                                  | 3      | 72.5                             | 43.1                  | 740                        | 0                     | 27                                           | 0.0         |
| 1st Elev.                                   | 2      | 72.5                             | 47.0                  | 807                        | 0                     | 28                                           | 0.0         |
| Main Lobby                                  | 9      | 72.6                             | 45.0                  | 852                        | 0                     | 25                                           | 0.0         |
| 1st Lobby                                   | 2      | 72.8                             | 46.5                  | 940                        | 0                     | 22                                           | 0.0         |
| Principal Office                            | 1      | 73.0                             | 47.2                  | 945                        | 0                     | 12                                           | 0.0         |
| Conference Rm                               | 3      | 72.7                             | 45.1                  | 827                        | 0                     | 28                                           | 0.0         |
| Girls Rm (Hall)                             |        | 73.2                             | 43.7                  | 620                        | 0                     | 23                                           | 0.0         |
| Boys Rm (Hall)                              |        | 73.5                             | 43.5                  | 819                        | 0                     | 22                                           | 0.0         |
| <b>Guideline levels<br/>ASHRAE/AIHA/EPA</b> |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/10/02

CITY\_21MC100\_002894063

**ATC ASSOCIATES, INC.**  
**INDOOR AIR QUALITY FIELD REPORT**

Page 2 of 2


TIME 1300

LOCATION PS150M DATE 5/10/02 PROJECT NO. 19125-0289

| Location                                   | Occup. | Temperature (°F)                   | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates(ug/m <sup>3</sup> ) | TVOCs (ppm) |
|--------------------------------------------|--------|------------------------------------|-----------------------|----------------------------|-----------------------|---------------------------------------------|-------------|
| Elevator Lobby (Hall)                      |        | 73.5                               | 43.4                  | 1040                       | 1                     | 27                                          | 0.1         |
| Reception Room                             |        | 73.2                               | 42.3                  | 1044                       | 1                     | 23                                          | 0.1         |
| Nurses Rm                                  | 2      | 73.6                               | 42.4                  | 1005                       | 1                     | 24                                          | 0.1         |
| Kitchen                                    |        | 72.5                               | 41.0                  | 1074                       | 1                     | 21                                          | 0.1         |
| Hall of Stairs                             |        | 74.4                               | 41.2                  | 1131                       | 1                     | 20                                          | 0.1         |
| Music Rm                                   | 24     | 73.4                               | 38.1                  | 1500                       | 1                     | 26                                          | 0.1         |
| 404                                        | 23     | 75.0                               | 46.4                  | 1163                       | 1                     | 20                                          | 0.1         |
| 404 (Hall)                                 |        | 74.8                               | 44.0                  | 1028                       | 1                     | 27                                          | 0.1         |
| 405                                        | 20     | 74.8                               | 43.4                  | 1011                       | 1                     | 20                                          | 0.1         |
| 405 Rm (Hall)                              |        | 74.8                               | 40.8                  | 805                        | 1                     | 26                                          | 0.1         |
| <b>Guideline levels</b><br>ASHRAE/AIHA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average     | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 5/10/02

CITY\_21MC100\_002894064

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 2TIME 12LOCATION PS150M DATE 5/10/02 PROJECT NO. 19125-0289

| Location                            | Occup. | Temperature (°F)                 | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|----------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| 4th Floor (Hall)                    |        | 75.0                             | 39.3                  | 810                        | 1                     | 20                                           | 0.1         |
| 4th Floor (Hall)                    |        | 75.1                             | 39.0                  | 748                        | 1                     | 20                                           | 0.1         |
| 402                                 |        | 74.1                             | 41.4                  | 736                        | 1                     | 52                                           | 0.1         |
| 401                                 | 33     | 74.3                             | 43.0                  | 1074                       | 1                     | 24                                           | 0.1         |
| 4th Floor (Hall)                    |        | 72.5                             | 41.0                  | 1132                       | 1                     | 28                                           | 0.1         |
| 501                                 |        | 73.7                             | 45.2                  | 1080                       | 1                     | 30                                           | 0.1         |
| 502                                 |        | 73.4                             | 42.5                  | 1035                       | 1                     | 22                                           | 0.1         |
| 5th Floor (Hall)                    |        | 74.0                             | 42.0                  | 810                        | 1                     | 26                                           | 0.1         |
| 503                                 | 21     | 74.2                             | 45.0                  | 1260                       | 1                     | 22                                           | 0.1         |
| 504                                 | 3      | 74.3                             | 48.5                  | 1100                       | 1                     | 24                                           | 0.1         |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 5/10/02