

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 1 of 4

Time: 1:10 pm LOCATION: PS ISC DATE: 5/31/02 PROJECT NO: 11125-0201

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
MAIN REJCT	1	71.6	47.4	659	1	22	C
MAIN REJCT	3	74.5	47.6	626	1	19	C
NEXT TO GESSI STAIRS HALL	0	77.6	46.5	726	1	18	C
MAIN LOBBY	4	79.3	46.5	715	1	18	C
LOBBY REJCT	1	72.1	45.1	160	1	18	C
MAIN OFFICE	3	69.8	40.6	704	1	19	C
EVIDENCE Room	1	76.2	43.4	654	1	76	C
NEXT TO BOYS FUR HALL	0	76.2	46.2	664	1	15	C
NEXT TO GESSI FUR HALL	0	77.2	47.6	716	1	11	C
NEXT TO EAST STAIRS HALL	0	77.5	47.8	696	1	12	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 7

Time: 4:40 pmLOCATION: 125 1st StDATE: 5/31/02 PROJECT NO: 1711-0005

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource Room	0	13.1	46.7	677	1	12	C
N. P. R. Room	1	74.1	46.4	703	1	11	C
File Room	2	72.9	46.3	710	1	5	C
Musik Room	1	72.0	47.1	651	1	10	C
Next to MCP Bank	1	73.0	45.1	709	1	10	C
4C4	25	73.9	45.5	1109	1	5	C
4C5	15	73.7	46.1	591	1	7	C
4C3 Hallway	3	73.1	46.3	741	1	10	C
Next to Boys Rest Room	0	73.1	46.1	702	1	10	C
Next to Girls Rest Room	1	73.2	45.5	599	1	10	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5/31/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page ²³ of 4

Time: 2:00 pm LOCATION: P5 150 DATE: 5/31/02 PROJECT NO: 19125-C287

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO STAIR Rm	C	78.1	40.3	1093	1	16	C
402	C	77.5	45.0	765	1	10	C
401	25	77.5	45.2	867	1	10	C
HALL BY WEST STAIRS	C	77.6	40.0	1041	1	16	C
501	35	76.1	42.1	977	1	17	C
502	20	76.1	41.2	1076	1	11	C
503	21	75.2	35.8	1007	1	9	C
504	25	75.4	38.3	1055	1	15	C
504 HALLWAY	C	77.9	41.1	1043	1	15	C
HALL BY EAST STAIRS	C	78.7	39.4	1026	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/31/02

**ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT**

Page 4 of 4

Time: 2:25 pm LOCATION: P-150 DATE: 5/31/02 PROJECT NO: 4125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
<u>OUTSIDE</u>							
<u>SOUTH SIDE</u>	<u>10</u>	<u>85.7</u>	<u>52.0</u>	<u>507</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>SOUT EAST CORNER</u>	<u>3</u>	<u>85.7</u>	<u>52.0</u>	<u>541</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>EAST SIDE</u>	<u>0</u>	<u>85.9</u>	<u>52.0</u>	<u>546</u>	<u>1</u>	<u>25</u>	<u>0</u>
<u>NORTHEAST CORNER</u>	<u>0</u>	<u>85.9</u>	<u>52.0</u>	<u>546</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>EAST TOP OF STAIRS</u>	<u>0</u>	<u>85.0</u>	<u>52.0</u>	<u>543</u>	<u>1</u>	<u>26</u>	<u>0</u>
<u>NORTHWEST CORNER</u>	<u>0</u>	<u>85.9</u>	<u>52.0</u>	<u>541</u>	<u>1</u>	<u>26</u>	<u>0</u>
<u>WEST SIDE</u>	<u>1</u>	<u>85.9</u>	<u>52.0</u>	<u>547</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>MAIN ENTRANCE</u>	<u>2</u>	<u>86.1</u>	<u>52.0</u>	<u>551</u>	<u>1</u>	<u>22</u>	<u>0</u>
<u>NEXT TO TOP OF STAIRS</u>	<u>0</u>	<u>86.1</u>	<u>52.0</u>	<u>561</u>	<u>1</u>	<u>24</u>	<u>0</u>
<u>NORTH SIDE</u>	<u>0</u>	<u>86.5</u>	<u>52.1</u>	<u>601</u>	<u>1</u>	<u>24</u>	<u>0</u>
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/31/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4

Time: 3:00 PM LOCATION: PS 150

DATE: 5/28/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Resource Rm	2	77.1	45.0	599	1	15	C
Nurse Rm	1	78.1	45.1	610	1	17	C
Kitchen	1	76.1	44.9	586	1	12	C
Music Rm	6	76.3	44.6	691	1	15	C
Next to sleep sink	1	76.7	44.3	499	1	11	C
404	C	77.3	45.7	526	1	11	C
403	C	77.4	46.1	540	1	9	C
403 Next to Boys Rm	C	76.1	46.3	601	1	8	C
403 Next to Girls Rm	C	76.1	46.1	571	1	11	C
403 403 Hallway	C	76.4	47.9	539	1	11	C
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: K. Zyzanski

Date: 5/28/02