

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4Time: 1:00 PMLOCATION: P-150DATE: 6/6/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>OUTSIDE</u>							
<u>SOUTH SIDE</u>	<u>20</u>	<u>85.5</u>	<u>54.0</u>	<u>576</u>	<u>1</u>	<u>33</u>	<u>0</u>
<u>SOUT. EAST CORNER</u>	<u>0</u>	<u>85.6</u>	<u>54.0</u>	<u>540</u>	<u>1</u>	<u>33</u>	<u>0</u>
<u>EAST SIDE</u>	<u>10</u>	<u>85.5</u>	<u>54.0</u>	<u>579</u>	<u>1</u>	<u>29</u>	<u>0</u>
<u>NORTHEAST CORNER</u>	<u>0</u>	<u>85.5</u>	<u>54.0</u>	<u>526</u>	<u>1</u>	<u>30</u>	<u>0</u>
<u>EAST TOP OF STAIRS</u>	<u>10</u>	<u>85.8</u>	<u>54.0</u>	<u>530</u>	<u>1</u>	<u>31</u>	<u>0</u>
<u>NORTHWEST CORNER</u>	<u>1</u>	<u>85.9</u>	<u>53.6</u>	<u>551</u>	<u>1</u>	<u>33</u>	<u>0</u>
<u>WEST SIDE</u>	<u>5</u>	<u>86.0</u>	<u>53.7</u>	<u>560</u>	<u>1</u>	<u>28</u>	<u>0</u>
<u>MAIN ENTRANCE</u>	<u>1</u>	<u>86.0</u>	<u>53.6</u>	<u>562</u>	<u>1</u>	<u>26</u>	<u>0</u>
<u>NEXT TO TOP OF STAIRS</u>	<u>5</u>	<u>86.1</u>	<u>53.6</u>	<u>579</u>	<u>1</u>	<u>28</u>	<u>0</u>
<u>NORTH SIDE</u>	<u>0</u>	<u>86.0</u>	<u>53.6</u>	<u>580</u>	<u>1</u>	<u>31</u>	<u>0</u>
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/6/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 40

Time: 1:30 PM LOCATION: PS 150 DATE: 6/6/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource room	2	77.2	54.4	947	1	17	C
Nurse room	1	77.3	56.2	906	1	15	C
Kitchen	1	77.8	51.1	621	1	12	C
Music room	25	76.7	52.3	911	1	17	C
NEXT TO SLOP SINK	0	78.5	52.0	561	1	16	C
404	0	78.6	42.5	805	1	15	C
403 HALLWAY	0	78.2	43.2	819	1	9	C
Out Doors 403 CLASSROOM	25	78.4	46.1	1002	1	15	C
Out Doors NEXT TO BOYS RM	0	78.8	47.2	981	1	15	C
Out Doors NEXT TO GIRLS ROOM	0	78.9	47.3	916	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/6/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4

Time: 4:40 pm

LOCATION: PS 15C

DATE: 6/6/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
MAIN Foyer	0	77.7	51.9	877	1	11	0
MAIN REAR	1	76.1	51.6	818	1	16	C
NEXT TO WEST STAIRS HALL	0	75.3	52.3	601	1	10	C
MAIN LOBBY	3	75.3	49.0	629	1	12	C
EDS ROOM	1	75.4	51.4	601	1	15	C
MAIN OFFICE	3	75.5	46.4	826	1	15	C
EVIDENCE ROOM	1	75.2	50.8	783	1	10	C
NEXT TO BOYS PUB HALL	0	75.7	55.1	749	1	11	C
NEXT TO GIRLS PUB HALL	0	76.1	55.6	930	1	18	C
NEXT TO EAST STAIRS HALL	0	76.4	55.7	866	1	17	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 6/6/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4

Time: 2:10 PM LOCATION: PS 150 DATE: 6/6/02 PROJECT NO: 19125-0989

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO STAFF ROOM	0	79.6	46.5	598	1	17	C
402	1	77.0	44.6	626	1	12	C
401	0	77.3	46.8	629	1	10	C
HALL BY WEST STAIRS 5TH FLOOR	0	79.1	45.6	699	1	11	C
501	25	78.9	45.3	1012	1	18	C
502	20	80.5	41.6	840	1	13	C
503	1	78.8	41.4	976	1	13	C
504	2	78.8	42.5	1264	1	16	C
504 HALLWAY	0	79.3	45.4	701	1	11	C
HALL BY EAST STAIRS	0	79.4	45.3	607	1	12	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/6/02