

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

Time: 1:10 pm LOCATION: P-150 DATE: 6/13/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
OUTSIDE							
SOUTHSIDE	10	72.3	46.1	518	1	36	0
SOUT EAST CORNER	0	72.3	46.3	586	1	36	0
EASTSIDE	16	72.3	46.4	819	1	32	0
NORTHEAST CORNER	2	72.3	46.1	616	1	34	0
EAST TOP OF STAIRS	10	72.3	46.2	649	1	31	0
NORTHWEST CORNER	0	72.3	46.2	604	1	33	0
WESTSIDE	3	72.8	46.2	641	1	30	0
MAIN ENTRANCE	1	72.8	46.2	588	1	30	0
NEXT TO TOP OF STAIRS	4	72.8	46.2	626	1	29	0
NORTHSIDE	1	72.3	46.2	596	1	31	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/13/02

CITY_21MC100_002894269

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

Time: 1:30 pm

LOCATION:

PS ISC

DATE: 6/13/02

PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
MAIN REAR	1	76.5	47.7	641	1	19	0
MAIN DESK	1	76.5	47.7	601	1	18	0
NEXT TO WEST STAIRS HALL	0	75.1	48.1	606	1	19	0
MAIN LOBBY	4	76.6	47.3	749	1	20	0
EXS ROOM	1	75.1	47.9	621	1	21	0
MAIN OFFICE	3	73.1	47.6	727	1	16	0
EVIDENCE ROOM	1	75.9	49.9	610	1	16	0
NEXT TO BOYS Rm HALL	0	75.7	47.7	581	1	11	0
NEXT TO GIRLS Rm HALL	0	75.8	47.6	561	1	12	0
NEXT TO EAST STAIRS HALL	0	75.8	47.6	588	1	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *[Signature]*

Date: 6/13/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4

Time: 2:01 pm LOCATION: PS 150 DATE: 4/13/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO STAFF RM	1	76.0	44.5	712	1	18	0
402	23	76.9	46.0	1081	1	16	0
401	24	76.5	46.3	1140	1	16	0
HALL BY WEST STAIRS	3	76.1	49.1	671	1	17	0
501	25	74.4	41.3	1262	1	18	0
502	26	74.6	43.4	1162	1	12	0
503	20	76.0	43.2	1589	1	13	0
504	22	76.3	43.4	1291	1	16	0
504 HALLWAY	0	75.7	44.9	586	1	11	0
HALL BY EAST STAIRS	0	75.9	44.9	603	1	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/13/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10 4

Time: 2:30 pm LOCATION: PS 150 DATE: 6/13/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Resource room	2	75.4	45.9	689	1	16	0
Nurse room	1	75.7	45.9	599	1	13	0
Kitchen	2	72.1	45.6	707	1	11	0
Music room	1	74.9	45.7	601	1	10	0
NEXT TO SLOP SINK	0	75.6	46.3	586	1	16	0
404	28	73.1	45.7	1131	1	15	0
403 Hallway	2	75.4	45.3	701	1	17	0
Out Doors 403 classroom	25	74.1	45.1	1020	1	11	0
Out Doors NEXT TO BOYS RM	0	75.6	46.4	601	1	16	0
Out Doors NEXT TO GIRLS RM	0	75.9	46.5	591	1	15	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 6/13/02