NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Time: 1 00 pm LOCATION: F- 150 DATE: 6/18/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
OUTSIDE							
SOUTHSIDE	3	78.1	32,3	591	2	31	0
SOUTH EAST CORNER	6	78.9	32,3	626	2	32	0
EASTSIDE	0	79.4	32,3	586	2	31	0
NORTHEAST CORNER	16	79.6	32,1	789	2	29	0
EAST TOP OF STAIRS	0	79.2	32,3	571	2	27	0
NORTHWEST CORNER	10	79.1	32,4	729	2	29	0
WESTSIDE	1	79.3	32,4	610	2	29	0
MAIN ENTRANCE	3	79.5	32,4	631	2	29	0
NEXT TO TOP OF STAIRS	4	79.4	32,4	645	2	30	0
NORTHSIDE	0	79.2	32,6	599	2	30	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

( ) location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

11 1115/m

CITY_21MC100_002894296

NYC-WTC_000178795

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Time: 1:30 pm LOCATION: PS 150 DATE: 6/18/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
MAIN FOYER	1	74.1	38.8	586	2	16	0
MAIN DESK	2	74.3	39.1	610	2	10	0
NEXT TO WEST STAIRS HALL	0	74.1	39.6	601	2	11	0
MAIN LOBBY	3	74.4	38.4	660	2	12	0
BUS FOYER	1	72.3	37.7	599	2	16	0
MAIN OFFICE	2	71.6	38.6	626	2	17	0
GUIDANCE Room	3	72.4	39.9	649	2	13	0
NEXT TO BOYS RR HALL	0	73.9	39.9	605	2	11	0
NEXT TO GIRLS RR HALL	0	73.9	38.1	586	2	13	0
NEXT TO EAST STAIRS HALL	0	74.1	38.6	577	2	16	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: [signature] Date: 6/18/02

CITY_21MC100_002894297

NYC-WTC_000178796

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Time: 150 pm LOCATION: PS 150 DATE: 6/18/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
HALLWAY NEXT TO STAFF RM	0	73.4	38.1	586	2	16	0
4C2	16	71.6	377	1091	2	17	0
4C1	12	71.9	38.1	1126	2	12	0
HALL BY WEST STAIRS	0	72.3	376	610	2	11	0
5C1	23	72.1	379	1137	2	13	0
502	21	73.6	379	1023	2	15	0
503	19	72.4	35.2	1261	2	15	0
504	21	71.6	35.2	1373	2	11	0
504 HALLWAY	0	73.6	37.3	589	2	9	0
HALL BY EAST STAIRS	1	73.4	38.1	626	2	10	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 6/18/02

CITY_21MC100_002894298

NYC-WTC_000178797

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Time: 2:30 pm LOCATION: PS 150 DATE: 6/18/02 PROJECT NO: 19125-0289

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Resource Room	1	72.4	36.6	621	2	17	0
NURSE ROOM	1	73.1	36.9	631	2	16	0
Kitchen	1	70.1	36.5	616	2	15	0
MUSIC ROOM	2	71.6	34.7	671	2	13	0
NEXT TO SLOP SINK	0	72.3	36.1	589	2	11	0
404	13	72.4	35.7	1026	2	14	0
403 Hallway	6	72.4	37.0	809	2	10	0
Out Doors 403 classroom	23	72.1	36.9	1126	2	15	0
Out Doors NEXT TO BOYS RM	0	72.6	36.0	610	2	17	0
Out Doors NEXT TO GIRLS ROOM	0	72.5	36.1	603	2	16	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: _____ Date: 6/18/02

CITY_21MC100_002894299

NYC-WTC_000178798