

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1TIME 8:07LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOCs (ppm)
Ext. Main Entr.		54.0	29.7	422	3	69	0.0
Ext. Main Entr. Sweets		53.7	29.3	418	3	72	0.0
Ext. Main Entr. North		53.4	30.1	412	3	85	0.0
10th fl. Hallway	1	66.2	31.8	473	1	12	0.0
Library	0	65.1	30.7	402	2	13	0.0
R. 1006	3	65.9	30.3	423	2	14	0.0
10th fl. Staircase A	0	65.9	32.9	638	2	8	0.0
9th fl. Hallway	0	67.0	32.4	554	2	13	0.0
R. 915	4	66.9	31.4	595	2	21	0.0
R. 904	3	67.2	29.8	501	2	17	0.0
Guideline levels ASHRAE/AHIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Medinech Date: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395228

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of __

TIME 8:31LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
8th fl. Hallway	1	65.6	36.2	704	2	6	0.0
Kitchen	4	70.4	35.5	824	2	9	0.0
Cafeteria	0	70.9	35.9	722	2	6	0.0
8th fl. Staircase A	0	70.1	34.3	764	2	7	0.0
7th fl. Hallway	1	70.9	31.3	666	2	9	0.0
R. 705	19	71.6	32.4	721	2	7	0.0
R. 706	33	71.9	31.7	779	2	16	0.0
R. 704	18	72.8	30.4	771	2	6	0.0
R. 703	27	73.3	31.9	901	2	5	0.0
7th fl. Hallway	0	69.6	30.8	816	3	4	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Medinich Date: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395229

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of TIME 8:59LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
R. 605	29	74.5	32.0	975	2	4	0.0
R. 604	31	75.6	31.3	993	2	9	0.0
R. 606	27	75.4	30.3	940	2	3	0.0
R. 608	13	75.4	30.6	1087	3	6	0.0
Staircase A 6th fl.	8	75.7	31.5	1312	3	10	0.0
5th fl. Hallway	3	75.7	30.0	1043	3	5	0.0
R. 507	10	75.2	27.6	805	3	6	0.0
R. 509	28	75.5	29.2	998	3	25	0.0
Staircase B 5th fl.	0	70.0	25.2	677	3	25	0.0
4th fl. Hallway	2	69.8	28.3	913	3	3	0.0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Needles Date: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395230

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of TIME 9:27LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
R. 404	3	72.9	28.5	701	2	3	0.0
R. 405	3	74.8	28.4	705	2	3	0.0
R. 406	28	75.4	29.6	859	2	3	0.0
3rd fl. Hallway	0	70.6	28.8	773	4	4	0.0
R. 304	1	73.1	28.5	687	2	2	0.0
R. 305	2	74.8	28.6	716	2	3	0.0
R. 308	23	75.4	30.2	893	2	3	0.0
R. 309	21	76.4	31.1	983	2	6	0.0
Staircase A 3rd fl.	2	76.0	29.2	899	3	5	0.0
2nd fl. Hallway	0	76.3	27.6	874	3	3	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: W. Medeiros Date: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395231

ATC ASSOCIATES, INC.

Page 5 of

INDOOR AIR QUALITY FIELD REPORT

TIME 9:51LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m ³)	TVOCs (ppm)
R. 208	21	77.6	28.0	1024	3	4	0.0
R. 204	30	77.0	26.7	831	3	8	0.0
R. 205	2	77.0	25.3	710	3	7	0.0
Bsm Hallway	0	76.9	26.8	917	3	9	0.0
Gym	73	75.1	30.2	1095	3	10	0.0
Auditorium	26	76.1	25.8	873	3	16	0.0
1st fl. Main Lobby	7	76.2	26.4	919	3	21	0.0
Ext. Main Entry		57.9	23.3	452	3	103	0.0
Ext. Main Entry South		58.3	24.1	450	4	97	0.0
Ext. Main Entry North		58.5	24.6	441	4	97	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. WeidnerDate: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395232

ATC ASSOCIATES, INC.

Page 6 of TIME 17:03

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Ext. Main Entr.		59.6	28.4	624	2	79	0.0
Ext. Main Entr. South		61.8	28.7	596	2	84	0.0
Ext. Main Entr. North		60.4	29.4	647	2	108	0.0
10th fl. Hallway	0	69.9	30.7	580	2	10	0.0
Library	0	68.4	29.6	627	2	10	0.0
R. 1006	0	69.6	30.1	684	2	8	0.0
10th fl. Staircase	0	71.06	31.4	696	2	6	0.0
9th fl. Hallway	0	72.8	31.7	671	2	6	0.0
R. 915	0	70.4	30.8	597	2	11	0.0
R. 904	0	69.9	28.9	588	2	20	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: M. KeddickDate: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395233

ATC ASSOCIATES, INC.

Page 7 of TIME 17:26

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
8th Fl. Hallway	2	71.9	35.8	756	2	5	0.0
Kitchen	0	73.4	34.7	876	2	10	0.0
Cafeteria	0	72.1	35.4	788	2	7	0.0
8th Fl. Staircase	0	72.1	33.9	806	2	7	0.0
7th Fl. Hallway	1	74.1	30.8	711	2	11	0.0
R. 705	6	74.9	31.2	804	2	7	0.0
R. 706	3	73.8	30.8	823	2	18	0.0
R. 704	12	75.6	29.9	901	2	7	0.0
R. 703	0	76.4	30.6	1020	1	5	0.0
7th Fl. Hallway	0	72.7	29.7	931	2	8	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Mediner Date: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395234

ATC ASSOCIATES, INC.

Page 8 of TIME 17:48

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
R. 605	6	77.3	31.3	1011	2	4	0.0
R. 604	12	77.9	30.1	1123	2	10	0.0
R. 606	5	76.9	30.3	1006	2	4	0.0
R. 608	0	78.3	30.5	1236	2	5	0.0
Staircase A 6th fl.	0	77.2	30.8	1420	2	8	0.0
5th fl. Hallway	0	76.8	29.6	1331	3	9	0.0
R. 507	11	76.9	26.4	921	3	6	0.0
R. 509	4	77.4	28.2	1027	3	23	0.0
Staircase B 5th fl.	0	72.8	24.5	784	3	4	0.0
4th fl. Hallway	0	73.6	27.2	979	3	8	0.0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: W. NiedrichDate: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395235

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 9 of TIME 18:06LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
R. 404	0	74.6	27.3	812	2	2	0.0
R. 405	2	75.8	27.2	793	2	2	0.0
R. 406	21	76.6	28.8	927	2	2	0.0
3rd fl. hallway	0	73.2	28.4	880	2	5	0.0
R. 304	1	74.6	28.1	811	2	2	0.0
R. 305	1	76.2	27.9	927	2	3	0.0
R. 308	11	76.1	29.6	984	2	3	0.0
R. 309	0	78.7	31.0	1012	2	3	0.0
Staircase A 3rd fl.	0	77.8	29.8	937	2	4	0.0
2nd fl. hallway	0	76.8	28.6	896	2	5	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: U. Mednick Date: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395236

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 10 of TIME 18:37LOCATION 100 TrinityDATE 3-7-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
R. 208	6	79.2	27.9	1142	3	2	0.0
R. 204	1	78.6	25.1	983	3	6	0.0
R. 205	1	77.9	24.9	826	3	7	0.0
Bsm Hallway	0	78.1	25.3	993	3	10	0.0
Gym	8	77.2	29.9	1259	3	10	0.0
Auditorium	0	77.1	26.3	984	3	11	0.0
1st. Fl. Main lobby	9	78.0	26.1	1101	3	22	0.0
Ext. Main Entry		60.4	24.4	621	3	112	0.0
Ext. Main Entry South		59.7	25.1	684	4	86	0.0
Ext. Main Entry North		59.0	23.5	655	3	80	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. MedickDate: 3-7-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003395237