



104 East 25th St., 10th Floor
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

May 1, 2002

Mr. Bernard P. Orlan
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

**Re: Dust Sampling for Asbestos
I.S. 306X
40 West Tremont Avenue
Bronx, New York 10453
ATC Project No. 19125-0246**

Dear Mr. Orlan:

As per your request, ATC Associates, Inc. representative Mr. Yiannis Efstathiou (NYC-DEP Asbestos Investigator #82244) visited I.S. 306X located at 40 West Tremont Avenue, Bronx, NY 10007 on April 28, 2002. The purpose of the site visit was to collect bulk samples from dust within several HVAC units throughout the school.


A total of eighteen (18) samples were collected from various HVAC units. All samples were analyzed utilizing Polarized Light Microscopy (PLM) methodology. No asbestos was detected in any of the eighteen (18) bulk samples collected.

Attached please find the following:

- Bulk sample and chain of custody form and laboratory results
- Laboratory and personnel certificates

If you have any questions or require additional information regarding this asbestos bulk sampling, please do not hesitate to contact me at (212) 353-8280 extension 211.

Sincerely,
ATC Associates, Inc.


Yiannis Efstathiou
Senior Project Manager

S:\WP\14584\IS306X bulk sampling HVAC.doc

CONFIDENTIAL,

CITY_21MC100_003391469

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008