

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/2/02 6:00:00 PM
ATC Group #: 7937
Analysis Date: 6/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
04 7937 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
05 7937 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
06 7937 -3	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
07 7937 -4	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
08 7937 -5	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
09 7937 -6	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046
10 7937 -7	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 3

CONFIDENTIAL,

CITY_21MC100_003456400

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/2/02 6:00:00 PM
ATC Group #: 7937
Analysis Date: 6/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
11 7937 -8	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
12 7937 -9	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
13 7937 -10	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
14 7937 -11	1888.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
15 7937 -12	1896.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 7937 -13	1896.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
17 7937 -14	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
18 7937 -15	1872.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
19 7937 -16	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 2 of 3

CONFIDENTIAL,

CITY_21MC100_003456401

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 6/2/02 6:00:00 PM
ATC Group #: 7937
Analysis Date: 6/2/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
20 7937 -17	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
21 7937 -18	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879