

ATC ASSOCIATES, INC.

Page 1 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S. (M477) DATE 12/31/01 PROJECT NO. 19/25-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside by the main entrance						30	
1st fl. Lobby						16	
Auditorium						18	
1st fl. Hallway by the Custodian's office						15	
1st fl. West Stairs						20	
1st fl. hallway North West side						21	
Pool area						7	
1st fl. Stairs next to the Pool						21	
1st fl. East Stairs						19	
1st fl. Hallway South to North						15	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Abo Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457346

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 10

TIME _____

LOCATION Stuyvesant H.S. (M477) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
2nd fl. Lobby						18	
2nd fl. hallway to South West						19	
Rm. 237						16	
Rm. 229						15	
Rm 231						13	
2nd fl. West Stairs						19	
2nd fl hallway South to North						20	
Rm 260						17	
2nd fl. East Stairs						22	
Rm 205						12	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457347

ATC ASSOCIATES, INC.

Page 3 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION New Stuyvesant H.S. (M474) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
3rd fl. Hallway by the elevator						17	
3rd fl. Aux Gym South						19	
3rd fl. Aux Gym North						20	
Rm 301						21	
3rd fl. East Stairs						22	
3rd fl. Hallway to North						17	
Rm 351						15	
3rd fl. Hallway South West						18	
Rm 373						18	
3rd fl. West Stairs						20	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457348

ATC ASSOCIATES, INC.

Page 4 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION New Stuyvesant H.S. (M477) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
4th fl. Hallway by the elevator						19	
Room 401						23	
Room 402						22	
4th fl. East Stairs						26	
Rm 411						19	
Rm 403						18	
Rm 431						17	
Rm 450						20	
4th fl. West Stairs						25	
4th fl. Hallway by Rm 431						19	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: H. Dubonja Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457349

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

TIME _____

LOCATION New Stuyvesant HS. (MATH) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
5th fl. Hallway by the elevator						17	
5th fl. Cafeteria						18	
5th fl. Hallway by the Cafeteria						19	
Rm. 513						16	
Rm 511						13	
Rm 503						15	
5th fl. East Stairs						19	
5th fl. Hallway to North						22	
5th fl. West Stairs						24	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73°-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Anderson Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457350

ATC ASSOCIATES, INC.

Page 6 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION New Stuyvesant HS (M477) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
6th fl. Hallway by the elevator						15	
6th fl. Gym						25	
6th fl. East Stairs						23	
Rm 615						14	
Rm 635						17	
Rm. 636						13	
Rm 638						13	
Rm 639						15	
6th fl. Hallway by the Rm 639						17	
						20	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Antony Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457351

ATC ASSOCIATES, INC.

Page 7 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION New Stuyvesant HS. (M477) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
7th fl. Hallway by the elevator						15	
7th fl. East Stairs						20	
Rm 701						21	
Rm 703						19	
Rm 731						16	
Rm 736						18	
Rm 738						20	
7th fl. Hallway by the Rm 738						17	
7th fl. West Stairs						20	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm.	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 12/31/01

CONFIDENTIAL, CITY_21MC100_003457352
 SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC.

Page 8 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION New Stuyvesant HS (M477) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
2th fl. Hallway by the elevator						16	
8th fl. East Stairs						19	
Rm 802						17	
Rm 815						19	
Rm 840						20	
2th fl. Hallway South West						21	
8th fl. West Stairs						25	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 12/31/01

CONFIDENTIAL,
 SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008
 CITY_21MC100_003457353

ATC ASSOCIATES, INC.

Page 9 of 10

TIME _____

INDOOR AIR QUALITY FIELD REPORT

LOCATION New Stuyvesant HS (M 477) DATE 12/31/01 PROJECT NO. _____

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
9th fl. Hallway by the elevator						18	
Rm 901						21	
9th fl. East Stairs						17	
Rm 902						18	
Rm 931						16	
Rm 935						15	
Rm 936						14	
Rm 938						17	
Rm 940						19	
9th fl. West Stairs						21	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *S. Anderson* Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457354

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 0 of 10

TIME _____

LOCATION New Stuyvesant HS (M477) DATE 12/31/01 PROJECT NO. _____

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOC (ppm)
10th fl. Hallway by the elevator						18	
Rm 1004						15	
Rm 1001						16	
Rm 1010						13	
Rm 1006						12	
Rm 1025						17	
Rm 1033						19	
10th fl. Hallway by the Rm 1033						20	
10th fl. West Stairs						25	
10th fl. East Stairs						23	
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Anthony Date: 12/31/01

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457355