

filter special
Page 1 of 2

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 1:35

LOCATION STUYVESANT HIGH SCHOOL

DATE 01/002

PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
739	32	75.6	28.4	965	1	22	0.0
740	-	74.4	25.6	695	1	29	0.0
738	2	75.2	28.0	1107	1	21	0.0
737	32	74.9	29.9	1165	1	23	0.0
736	10	75.4	29.8	1524	1	17	0.0
636	28	75.2	28.4	990	1	22	0.0
638	28	75.2	27.2	880	1	22	0.0
640	34	77.2	29.1	1099	1	18	0.0
639	-	76.7	27.4	852	1	20	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 01/002

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL

CITY_21MC100_003457577

Speed Filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 3

TIME 2:10

LOCATION STUYVESANT HIGH SCHOOL

DATE 01/00/02

PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
429	36	73.6	27.3	1011	1	25	0.0
431	26	73.2	26.3	950	1	24	0.0
433	34	75.4	27.3	960	1	20	0.0
435	1	73.8	24.3	580	1	19	0.0
436	12	73.3	24.8	640	1	18	0.0
437	34	73.2	26.2	890	1	24	0.0
439	36	73.8	27.3	1020	1	19	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 01/00/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457578

special filter

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3

TIME 2:45

LOCATION STUYVESANT HIGH SCHOOL

DATE 01/002

PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
339	20	72.3	25.9	828	1	20	0.0
337	34	71.9	26.6	967	1	21	0.0
336	26	73.2	26.9	753	1	19	0.0
335	34	73.2	27.8	989	1	22	0.0
333	32	73.0	28.4	1120	1	19	0.0
329	26	73.9	27.7	846	1	20	0.0
327	—	73.8	27.6	804	1	20	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 01/002

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003457579