NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC.

INDOOR AIR QUALITY FIELD REPORT

LOCATION : STUYVESANT HIGH SCHOOL **DATE** 02-11-02 **PROJECT NO.** 15-19125-0246

RESPIRABLE PARTICULATES (µg / m³)

In Rooms with portable HEPA air Purifier

Time /Location	Room 740	Room 638	Room 333	Room 327
7:50	14	14	15	14
9:00	16	15	16	16
10:00	17	16	16	17
11:00	16	15	15	16
12:00	16	16	15	16
13:00	15	16	15	15

CONFIDENTIAL,
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008
CITY_21MC100_0034578 17

NYC-WTC_000179076