

ATC Associates

104 West 111 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8506



Attn: Mr. Bernard Orian
 N.Y.C. Board of Education
 20-11 Queens Plaza North
 Long Island City, NY 11101

Received: 11/25/01 5:00:00 AM

ATC Group #: 5970

Analysis Date: 11/25/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (f/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
1 5970 -	36.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
2 5970 -	44.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
3 5970 -	44.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 5970 -	44.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 5970 -	36.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 5970 -	28.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 5970 -	20.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
8 5970 -	20.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

ROMAN RYSAKHOV

Approved by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003458385

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Edward Orlan
 Board of Education
 Queens Plaza North
 Long Island City, NY 11101

Received: 11/25/01 5:00:00 AM

Project Group #: 5970

Analysis Date: 11/25/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: John Jay High School, 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm²)	(S/cc)	
9 5970 - 9	28.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
10 5970 - 10	36.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
11 5970	36.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
12 5970 - 12	36.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
13 5970 - 13	36.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
14 5970 - 14	28.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
15 5970 - 15	28.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
16 5970 - 16	36.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
17 5970 - 17	28.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	
18 5970 - 18	28.00	0.0450	0	None Detected	0	0	0.0044	22.24	<0.0044	

ROMAN ENSAKHOV

Analyzed by:

RRig

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Michael A. Gorycki

Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003458386

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Bernard Orian
 Board of Education
 100-10 Queens Plaza North
 Long Island City, NY 11101

Received: 11/25/01 5:00:00 AM

ATC Group #: 5970

Analysis Date: 11/25/01

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: New Suyvesant H. S., 345 Chambers St., NY, NY
 Location: Interior and Interior of Building and Roof

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5u-5	5u		(S/mm ²)	(S/cc)	
19 5970	20.00	0.0450	0	None Detected	0	0	0.0045	22.24	<0.0044	
20 5970	20.00	0.0450	0	None Detected	0	0	0.0045	22.24	<0.0045	
21 5970	20.00	0.0450	0	None Detected	0	0	0.0045	22.24	<0.0045	


ROMAN MEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: This laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for: NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003458387

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008