

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/28/01 9:00:00 PM

ATC Group #: 5986

Analysis Date: 11/29/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
1 5986 -1	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
2 5986 -2	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
3 5986 -3	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 5986 -4	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 5986 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 5986 -6	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 5986 -7	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
8 5986 -8	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003458491

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/28/01 9:00:00 PM

ATC Group #: 5986

Analysis Date: 11/29/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
9 5986 -9	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 5986 -10	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 5986 -11	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
12 5986 -12	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
13 5986 -13	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 5986 -14	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 5986 -15	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
16 5986 -16	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
17 5986 -17	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
18 5986 -18	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003458492

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/28/01 9:00:00 PM

ATC Group #: 5986

Analysis Date: 11/29/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
19 5986 -19	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
20 5986 -20	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
21 5986 -21	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:

RRuy

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Michael A. Gorycki

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003458493

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008