



104 East 25th Street 10th FL
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

October 29, 2001

Mr. Bernard P. Orlan
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Re: Limited settled dust sampling for fiberglass at Stuyvesant HS (M477)

Dear Mr. Orlan:

At your request, ATC Associates, Inc. representative Mr. Yiannis Efstathiou visited Stuyvesant HS (M477) located at 345 Chambers Street, New York, NY 10007 on October 24th, 2001. The purpose of the site visit was to perform a settled dust sampling to be analyzed for fiberglass content on areas indicated in H.A. BADER Consultants, Inc. letter to Stuyvesant HS parents dated October 10, 2001. These areas are the following:

- 1st and 2nd floors lobby
- North, East and South exit vestibules
- Roof
- Classrooms with unit ventilators on the North, East and South side of the building
- Two hallway areas
- 1st floor swimming pool area
- 3rd floor gymnasium area
- 5th floor cafeteria area
- Auditorium area

The purposed of the dust sampling is to determine if settled dust in the school contains fiberglass fibers. ATC will be repeating this sampling every Wednesday as per the recommendation of H.A. BADER Consultants, Inc. and after the approval of NYC-BOE. This is the second week such a sampling is performed in Stuyvesant HS.

As per your request, a total of fifteen (15) settled dust samples, utilizing the Scotch Magic Tape – An Aid to the Microscopist for Dust Examination method by Gary Nichols, were collected from the aforementioned areas and were analyzed utilizing Polarized Light Microscopy (PLM). This method produces qualitative results only.

Analytical results indicated that none of the fifteen (15) collected settled dust samples contain fiberglass fibers.

CONFIDENTIAL,

CITY_21MC100_011532982

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008



104 East 25th Street 10th FL
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

The settled dust sampling performed was limited to testing for fiberglass in locations indicated by H.A. BADER Consultants, Inc. only.

Attached please find the following:

- Settled dust sample chain of custody form and laboratory results
- Laboratory and personnel certificates

If you have any questions or require additional information regarding this limited settled dust sampling, please do not hesitate to contact me at (212) 353-8280 extension #261.

Sincerely,

A handwritten signature in black ink, appearing to read 'Andreas C. Andreou', with a horizontal line extending from the end of the signature.

Andreas C. Andreou
Senior Project Manager

Cc: Mr. H. Bader (H.A. BADER Consultants, Inc.)
Ms. C. Procter (UFT)
Mr. C. D'Andrea (NYC-DOH)
Mr. S. Teitel (Principal of Stuyvesant HS)

CONFIDENTIAL,

CITY_21MC100_011532983

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008