

**ATC ASSOCIATES, INC**  
**104 E 25th Street, 10th Floor**  
**New York, NY 10010**  
**Tel. 212-353-8280**  
**Fax 212-353-8306**

---

**REPORT DATE:** 10-22-01  
**CLIENT:** NYC BOE  
**PROJECT ADDRESS:** Stuyvesant HS (M477)  
345 Chambers Street, New York, NY 10007  
**PROJECT NO:** 19125-0246  
**SAMPLED BY:** H. Antonyan  
**SAMPLE DATE:** 10-20-01  
**DATE RECEIVED:** 10-21-01  
**DATE ANALYZED:** 10-21-01  
**SAMPLE MEDIA:** Air Samples  
**ANALYSIS REQUIRED:** Method NIOSH 7082

---

**ANALYSIS RESULTS**

| SAMPLE ID | BATCH NO. | SAMPLE DESCRIPTION                  | LEAD CONCENTRATION ( $\mu\text{g}/\text{m}^3$ ) | DETECTION LIMIT |
|-----------|-----------|-------------------------------------|-------------------------------------------------|-----------------|
| 01        | 9556      | Field Blank                         | <1.6                                            | 1.6             |
| 02        | 9556      | Field Blank                         | <1.6                                            | 1.6             |
| 03        | 9556      | 1st Floor Swimming Pool Area        | <2.1                                            | 2.1             |
| 04        | 9556      | 1st Floor East Side Exit Vestibule  | <2.1                                            | 2.1             |
| 05        | 9556      | 1st Floor North Side Exit Vestibule | <2.1                                            | 2.1             |
| 06        | 9556      | 3rd Floor Aux. GYM Area             | <2.1                                            | 2.1             |
| 07        | 9556      | 5th Floor Cafeteria Area            | <2.1                                            | 2.1             |

NOTE 1:  
THE REPORTING LIMIT (RL) IS 3.2  $\mu\text{g}$

NOTE 2:  
At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30  $\mu\text{g}/\text{m}^3$  and a permissible exposure level (PEL) of 50  $\mu\text{g}/\text{m}^3$  for personal samples.

CONFIDENTIAL,  
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CITY\_21MC100\_003458836

ATC ASSOCIATES, INC  
104 E 25th Street, 10th Floor  
New York, NY 10010  
Tel. 212-353-8280  
Fax 212-353-8306

---

---

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: *[Signature]*

REPORT PREPARED BY: *[Signature]*

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: *[Signature]*

LABORATORY DIRECTOR: *[Signature]*

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).

CONFIDENTIAL,

CITY\_21MC100\_003458837

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008