



ATC ASSOCIATES INC.
 AIR SAMPLING - CHAIN OF CUSTODY
 104 EAST 25TH STREET, 10TH FLOOR
 NEW YORK, NEW YORK 10010
 PHONE: 212-353-8280 FAX: 212-979-8447

PAGE 1 OF 1

9556

Client: NYC-BOE	Project Address: Stuyvesant HS (M477) 345 Chambers Street, New York, NY 10007	Type: LEAD A: ☐ Pre/Baseline C: ☐ Post E: ☒ Ambient B: ☐ Durings D: ☐ OSHA F: ☐ Other	Date: 10/20/01
Project No: 19125-0246	Field Technician: H. ANTONYAN	Project Manager: Andreas C. Andreou	Turnaround Time: RUSH
		Cassette Lot No:	Rotameter No: LP-016

Sample ID Number	ATC Pump #	Sample Locations	Type	Time Start	Time End	Total Minutes	Flow Rate (L/Min) Start End Avg.	Total Air Volume (Liters)	Detection Limit	Results $\mu\text{g}/\text{m}^3$
M477-10/20-01		Field Blanks (Open)							1.5	<1.5
-02		Field Blanks (Closed)							1.5	<1.5
-03	389974	1st Floor Swimming Pool Area		8:35	12:36	241	3 3 3	723	2.1	<2.1
-04	389586	1st Floor East Side Exit Vestibule		8:37	12:38	241	3 3 3	723	2.1	<2.1
-05	389975	1st Floor North side Exit Vestibule		8:39	12:40	241	3 3 3	723	2.1	<2.1
-06	389997	3rd Floor Aux Gym Area		8:43	12:44	241	3 3 3	723	2.1	<2.1
-07	389998	5th Floor Cafeteria Area		8:45	12:47	242	3 3 3	731	2.1	<2.1

RELINQUISHED BY (SIGNATURE BELOW): 	DATE/TIME:	RECEIVED BY (SIGNATURE BELOW): 	DATE/TIME: 10/24/01	LABORATORY:
PRINT NAME: Jimmy Ching		PRINT NAME: Jim H. L. H.		NLLAP# ELAP#

swp/41617/turns:FEW-AIR AREA.XLS

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003458838