



104 East 25th Street
 New York, New York 10010
 www.atc-enviro.com
 212.353.8280
 Fax 212.353.8306

March 11, 2002

Mr. Bernard P. Orlan
 New York City Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Re: Limited Dust Sampling for Asbestos
 High School for Leadership and Public Service
 90 Trinity Place, New York, New York
 ATC Project No.: 14584.0864

Dear Mr. Orlan:

At your request, ATC Associates, Inc. representative Mr. Alex Kholodenko (NYC-DEP Asbestos Investigator # 86823 and NYS-DOL Asbestos Inspector Certificate #AH 97-09809) visited the High School for Leadership and Public Service located at 90 Trinity Place, New York, New York 10006 on March 6, 2002. The purpose of the site visit was to perform a dust sampling to be analyzed for asbestos content in the areas indicated by the Board of Education.

As per your request, a total of ten (10) dust samples, using 3M scotch tape and a glass slide, were collected in the following locations:

- Gymnasium HVAC diffusers => Five (5) samples
- Auditorium window sill => One (1) sample
- Auditorium HVAC diffusers => Four (4) samples

All ten (10) collected dust samples were analyzed utilizing Polarized Light Microscopy (PLM). See attached laboratory report.

Analytical results indicated that none of the ten (10) collected settled dust bulk samples contain asbestos fibers.

The settled dust bulk sampling performed was limited to testing for asbestos in the locations indicated by your office.

CONFIDENTIAL,

CITY_21MC100_003459143


SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attached please find the following:

- Dust sample chain of custody form and laboratory results
- Laboratory and personnel certificates

If you have any questions or require additional information regarding this limited asbestos dust sampling, please do not hesitate to contact me at (212) 353-8280 extension #261.

Sincerely,

A handwritten signature in black ink, appearing to read 'Arnel Javal', is written over the printed name.

Arnel Javal
Senior Project Manager

CONFIDENTIAL,

CITY_21MC100_003459144

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008