

ATC ASSOCIATES, INC.

Page 1 of 8

TIME 3:31

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity Pl

DATE 2-26-02

PROJECT NO. 19/25-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Exterior Main Entry		55.1	37.8	453	4	58	0.0
Main Lobby 1st Fl.	14	64.1	42.6	653	2	18	0.0
10th Fl. Hallway	0	69.4	41.7	457	2	8	0.0
Library Main 10th Fl. Room	0	70.0	41.3	630	2	9	0.0
Library Office R 1001	0	69.1	39.0	547	2	9	0.0
R 1006	0	70.4	38.2	470	2	8	0.0
R 1006	2	70.0	37.7	477	2	9	0.0
Staircase B 10th Fl.	0	65.2	35.1	450	3	32	0.0
9th Fl. Hallway	0	66.8	38.1	812	2	9	0.0
R 915	0	71.0	38.8	736	2	9	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Weckert

Date: 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL

CITY_21MC100_003459413

ATC ASSOCIATES, INC.

Page 2 of 8

TIME 3:54

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity PlDATE 2-26-02PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOCs (ppm)
R. 914	0	70.0	38.4	743	2	9	0.0
R. 913	1	70.1	38.5	614	2	8	0.0
R. 912	0	70.0	37.2	593	2	9	0.0
R. 911	0	69.4	36.5	483	2	9	0.0
R. 910	0	69.0	36.8	559	2	10	0.0
R. 909	0	68.6	36.9	532	2	8	0.0
R. 908	0	68.9	36.9	552	2	9	0.0
R. 907	0	68.9	36.8	523	2	9	0.0
R. 918	0	69.3	37.0	560	2	8	0.0
R. 917	0	69.6	36.6	491	2	8	0.0
Guideline levels ASHRAE/AMIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: M. Weidner Date: 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459414

ATC ASSOCIATES, INC.

Page 3 of 8

TIME 4:17

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity Pl DATE 2-26-02 PROJECT NO. 19/25-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m ³)	TVOC's (ppm)
R 900	0	69.9	36.3	512	2	8	0.0
R.904	2	69.6	36.2	504	2	9	0.0
R.903	0	70.7	36.7	516	2	8	0.0
Staircase B 9th fl.	0	68.6	33.8	527	3	24	0.0
8th fl. Hallway	4	69.7	39.3	731	3	12	0.0
R.801	1	71.7	38.8	641	2	12	0.0
Kitchen	4	74.8	45.9	791	2	17	0.0
Cafeteria	112	75.3	42.3	1178	3	9	0.0
Staircase A 8th fl.	0	75.1	38.4	1005	3	8	0.0
7th fl. Hallway	0	76.0	33.1	515	3	5	0.0
Guideline levels ASHRAE/AMIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments. _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Mednick Date: 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459415

ATC ASSOCIATES, INC.

Page 4 of 8

TIME 4:31

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity PL DATE 2-26-02 PROJECT NO. 19125-0291

Location	Occup,	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOCs (ppm)
R.705	0	75.9	31.8	480	3	4	0.0
R.706	0	75.9	31.7	476	3	6	0.0
R.704 A	0	76.3	31.1	481	2	5	0.0
R.704	0	76.4	31.3	553	2	5	0.0
R.703	0	76.4	30.6	508	3	4	0.0
R.702	0	75.9	30.9	499	2	7	0.0
Staircase B 7th fl.	0	69.6	29.8	484	4	16	0.0
6th fl. Hallway	3	71.6	32.4	987	3	4	0.0
R.603	2	74.5	35.1	887	2	5	0.0
R.604	1	76.1	32.6	562	2	5	0.0
Guideline levels ASHRAE/AMIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Weckert Date 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459416

ATC ASSOCIATES, INC.

Page 5 of 8

TIME 4:56

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity PlDATE 2-26-02PROJECT NO 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOC's (ppm)
R. 603	1	76.7	31.6	563	2	4	0.0
R. 608	0	77.9	31.0	895	2	5	0.0
R. 607	0	77.3	30.4	683	3	4	0.0
R. 606	0	77.1	30.1	507	3	4	0.0
Staircase A 6th fl.	0	78.1	31.6	745	3	5	0.0
5th fl.	0	78.8	29.8	571	3	6	0.0
Hallway R. 508	4	78.6	29.6	557	3	5	0.0
R. 507	0	78.1	28.7	597	3	4	0.0
R. 506	0	78.2	29.9	642	3	4	0.0
R. 505	0	77.9	32.1	584	2	5	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24 hour average	1 ppm

Comments. _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Medeiros Date: 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459417

TIME 5:28ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORTPage 6 of 8LOCATION 100 Trinity PlDATE 2-26-02PROJECT NO 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m ³)	TVOC's (ppm)
Staircase B 5th fl.	0	72.3	28.0	486	4	18	0.0
4th fl. Hallway	0	72.4	35.0	536	1	9	0.0
R. 402	0	73.4	29.9	621	2	2	0.0
R. 404	0	76.5	31.4	505	2	6	0.0
R. 405	0	77.4	30.5	503	2	16	0.0
R. 406	0	77.4	30.2	544	2	6	0.0
R. 410	0	78.4	30.0	530	2	6	0.0
R. 409	0	77.5	29.6	494	2	7	0.0
R. 408	0	77.2	29.4	484	3	7	0.0
R. 407	0	77.9	29.5	503	2	6	0.0
Guideline levels ASHRAE/AMIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments. _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: W. Medeiros Date 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459418

ATC ASSOCIATES, INC.

Page 7 of 8

TIME 5:56

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity PLDATE 2-26-02PROJECT NO 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOC's (ppm)
Staircase 4th fl.	0	78.8	29.5	523	2	5	0.0
3rd fl. Hallway	0	79.6	29.0	511	3	5	0.0
R. 307	1	79.1	28.6	493	3	6	0.0
R. 309	1	79.2	28.5	584	3	5	0.0
R. 306	0	79.1	28.4	505	3	5	0.0
R. 308	0	78.7	28.3	493	3	6	0.0
R. 305	1	79.2	28.4	542	3	5	0.0
R. 304	0	79.1	28.0	534	3	5	0.0
R. 303	0	78.9	28.3	651	3	6	0.0
Staircase B 3rd fl.	0	72.3	28.0	682	4	16	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature W. Weidner Date 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459419

ATC ASSOCIATES, INC.

Page 8 of 8

TIME 5:18

INDOOR AIR QUALITY FIELD REPORT

LOCATION 100 Trinity PL DATE 2-26-02 PROJECT NO. 19125-0291

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
2nd fl. Hallway	0	73.1	30.1	544	3	5	0.0
R. 203	0	75.1	30.5	486	2	5	0.0
R. 204	0	75.3	30.6	555	2	7	0.0
R. 205	0	75.8	30.4	527	2	5	0.0
R. 206	0	76.8	30.3	492	2	6	0.0
R. 207	0	76.7	30.3	564	2	7	0.0
Staircase B 2nd fl.	0	72.4	29.8	572	2	11	0.0
Auditorium 1st fl.	124	75.8	31.0	560	3	11	0.0
R. 209 Balcony	3	76.7	29.4	724	2	9	0.0
Main Lobby 1st fl.	4	72.3	32.6	764	2	18	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Mr. Meechie Date: 2-26-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003459420