

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 4/20/02 4:00:00 PM
ATC Group #: 7482
Analysis Date: 4/20/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
1 7482 -1	1808.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
2 7482 -2	1808.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
3 7482 -3	1816.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
4 7482 -4	1808.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
5 7482 -5	1808.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
6 7482 -6	1808.00	0.0450	0	None Detected	0	0	0.0047 <22.24 <0.0047	
7 7482 -7	1800.00	0.0450	0	None Detected	0	0	0.0048 <22.24 <0.0048	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879

Page 1 of 3

CONFIDENTIAL,

CITY_21MC100_003459754

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 4/20/02 4:00:00 PM
ATC Group #: 7482
Analysis Date: 4/20/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
8 7482 -8	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
9 7482 -9	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
10 7482 -10	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
12 7482 -12	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
13 7482 -13	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
14 7482 -14	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
15 7482 -15	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047
16 7482 -16	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
17 7482 -17	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 4/20/02 4:00:00 PM
 ATC Group #: 7482
 Analysis Date: 4/20/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ³)	(S/cc)	
18 7482 -18	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 7482 -19	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
20 7482 -20	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 7482 -21	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 3 of 3

CONFIDENTIAL,

CITY_21MC100_003459756

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008