

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 10

Time: 7:55 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Out Doors EXIT MAIN ENTRY	0	68.6	57.4	421	1	97	0
Out Doors EXIT MAIN ENTRY SOUTH	0	68.6	57.4	439	1	97	0
Out Doors EXIT MAIN ENTRY NORTH	0	68.6	57.4	467	1	98	0
10TH FLOOR HALLWAY	0	75.9	52.6	510	1	16	0
LIBRARY	0	77.0	51.6	574	1	12	0
R-1006	0	77.8	50.7	605	1	14	0
STAIRCASE A 9TH FLOOR	0	78.0	49.6	496	1	16	0
9TH FLOOR HALLWAY	0	77.4	50.6	471	1	17	0
R-915	0	78.0	50.8	49.8	1	15	0
Rm- 933	4	78.5	49.4	806	1	19	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462541

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 10

Time: 8:45 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room 914	2	79.4	47.5	579	1	11	C
STAIRCASE B 8TH FLOOR	C	78.6	46.4	419	1	16	C
8TH FLOOR HALLWAY	C	77.9	46.4	421	1	21	C
Kitchen	5	77.2	45.9	615	1	16	C
CAFETERIA	20	78.4	47.1	866	1	11	C
STAIRCASE A 7TH FLOOR	C	72.1	49.1	471	1	11	C
7TH FLOOR HALLWAY	C	77.9	46.1	426	1	9	C
Room 706	26	77.4	50.6	989	1	15	C
Room 704	21	77.3	52.1	815	1	15	C
Room 703	C	77.4	50.1	471	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462542

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 10

Time: 9:15 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-07 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 6TH FLOOR	C	78.5	50.4	481	1	23	C
6TH FLOOR HALLWAY	C	78.6	50.6	486	1	19	C
Room 604	28	77.9	50.5	1016	1	16	C
Room 605	22	77.7	50.3	989	1	15	C
Room 606	C	77.4	49.9	461	1	20	C
Room 608	16	78.2	50.6	868	1	21	C
STAIRCASE A 5TH FLOOR	C	78.9	49.9	491	1	16	C
5TH FLOOR HALLWAY	C	79.8	50.3	501	1	14	C
Room 509	26	75.9	51.6	1101	1	16	C
Room 507	15	76.5	52.5	919	1	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-10-07

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462543

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 4 of 10

Time: 9:35 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-07 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Rm 504	0	77.0	53.2	466	1	16	C
STAIRCASE B 4TH FLOOR	0	72.1	48.6	418	1	17	C
4TH FLOOR HALLWAY	0	71.7	47.6	431	1	21	C
Rm 405	3	75.9	51.6	731	1	22	C
Rm 406	4	75.0	52.2	526	1	23	C
Rm 410	1	76.6	52.6	599	1	16	C
Rm 409	2	76.6	52.6	610	1	14	C
STAIRCASE "A" 3RD FLOOR	0	73.6	49.8	455	1	11	C
Room 307	26	75.9	50.2	1012	1	16	C
Room 404	27	76.1	50.6	1146	1	16	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462544

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10Time: 10:07 AM LOCATION: 100 Trinity Place /HS for Economics And FinancesDATE: 5-10-02

PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 2ND FLOOR	0	71.6	48.6	471	1	16	0
Room 207	0	75.8	55.7	465	1	17	0
Room 204	0	75.6	55.9	427	1	16	0
2ND FLOOR HALLWAY SOUTH SIDE	0	72.6	49.9	432	1	15	0
GIM	0	72.6	49.6	517	1	21	0
AUDITORIUM	26	76.7	56.2	1134	1	26	0
1ST FLOOR LOBBY	6	72.2	61.6	791	1	49	0
Out Doors EXIT MAIN ENTRY	0	71.0	56.1	480	1	23	0
Out Doors EXT MAIN ENTRY SOUTH	0	71.1	56.1	480	1	24	0
Out Doors EXT MAIN ENTRY NORTH	0	71.1	56.7	481	1	21	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: NA

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462545

A

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 6 of 10

Time: 1:30 pm LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
Out Doors EXT MAIN ENTRY	0	80.1	28.1	421	1	24	0
Out Doors EXT MAIN ENTRY SOUTH	0	80.1	28.1	431	1	23	0
Out Doors EXT MAIN ENTRY NORTH	0	80.1	27.9	440	1	21	0
10TH FLOOR HALLWAY	0	75.6	48.6	475	1	13	0
LIBRARY	0	76.9	49.2	476	1	16	0
R 1006	4	76.9	51.1	816	1	12	0
STAIRCASE A 9TH FLOOR	0	78.1	50.9	491	1	16	0
9TH FLOOR HALLWAY	0	76.1	50.1	501	1	16	0
Rm 915	0	76.9	49.1	502	1	16	0
Rm 933	0	77.5	49.6	493	1	19	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462546

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 10

Time: 1:30 PM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Rm 904	4	78.6	49.3	669	1	12	C
STAIRCASE B 8TH FLOOR	0	78.1	49.6	510	1	16	C
8TH FLOOR HALLWAY	0	76.5	48.6	509	1	21	C
Kitchen	6	77.9	50.1	710	1	16	C
CAFETERIA	12	77.6	50.6	810	1	12	C
STAIRCASE A 7TH FLOOR	0	73.1	50.9	491	1	11	C
Room 706	22	77.6	51.1	863	1	11	C
Room 704	0	77.4	49.6	461	1	9	C
Room 703	0	78.1	49.9	440	1	16	C
7TH FLOOR HALLWAY	0	73.5	49.1	457	1	12	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: NA

assessed location(s) () Does () Does not meet established indoor air quality guidelines.

John F. [Signature]

Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462547

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 10

Time: 2:15 pm LOCATION: 100 Trinity Place / IIS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 6TH FLOOR.	1	76.1	49.9	479	1	22	C
6TH FLOOR. HALLWAY	6	72.3	49.6	669	1	20	C
Room 604	22	74.5	50.6	1260	1	17	C
Room 605	16	74.5	50.3	909	1	16	C
Room 608	20	73.6	50.1	1011	1	19	C
STAIRCASE A 6TH FLOOR.	2	74.1	48.9	710	1	18	C
5TH FLOOR ROOM 509	C	74.6	49.9	471	1	11	C
Room 606	C	73.3	51.6	486	1	14	C
5TH FLOOR HALLWAY	C	73.4	51.9	440	1	15	C
Room 507	C	73.6	50.1	451	1	16	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462548

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 9 of 10

Time: 2:26 LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room 504	0	76.1	50.1	461	1	17	0
STAIRCASE B- 4TH FLOOR	0	73.4	48.6	421	1	19	0
4TH FLOOR HALLWAY	0	72.1	47.6	436	1	21	0
Room 404	0	74.4	51.3	431	1	22	0
Room 405	16	73.9	49.9	901	1	23	0
Room 406	1	72.9	48.6	602	1	16	0
Room 410	2	73.3	49.9	626	1	14	0
Room 409	0	74.6	50.6	471	1	11	0
STAIRCASE A 3RD FLOOR	24	74.6	48.6	1011	1	16	0
Room 307	23	74.5	50.6	993	1	15	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: NA

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462549

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 10 of 10

Time: 2:30 pm LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-10-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 2ND FLOOR	0	72.6	48.6	426	1	16	C
Room 207	0	74.6	50.6	440	1	17	C
Room 204	16	75.1	49.8	436	1	18	C
2ND FLOOR HALLWAY NORTHSIDE	0	73.1	48.6	451	1	16	C
Gym	0	72.9	49.9	467	1	16	C
AUDITORIUM	0	77.1	51.6	444	1	21	C
1ST FLOOR LOBBY	4	76.9	51.0	719	1	22	C
Out Doors EXT MAIN ENTRY	0	80.1	25.2	410	1	16	C
Out Doors EXT MAIN ENTRY SOUTH	0	80.2	25.6	416	1	17	C
Out Doors EXT MAIN ENTRY NORTH	0	80.3	25.5	417	1	21	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-10-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462550