

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1

Time: 7:52 AM LOCATION: 100 Trinity Place /HS for Economics And Finances

DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Out Doors EXIT MAIN ENTRY	0	63.8	37.6	451	2	44	C
Out Doors EXIT MAIN ENTRY SOUTH	C	63.9	37.6	450	2	44	C
Out Doors EXIT MAIN ENTRY NORTH	C	63.8	37.6	450	2	44	C
10TH FLOOR HALLWAY	C	71.3	39.3	459	2	10	C
LIBRARY	1	71.2	38.4	676	2	11	C
R-1006	C	74.7	40.5	471	2	16	C
STAIRCASE A 9TH FLOOR	C	75.2	40.8	491	2	17	C
9TH FLOOR HALLWAY	C	76.2	43.2	501	2	9	C
R-915	C	76.3	43.4	499	2	12	C
Rm- 933	4	76.9	41.4	641	2	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: *[Signature]*

Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462570

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 10

Time: 8:35 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291


Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room 914	6	76.1	43.6	663	2	19	0
STAIRCASE B 8TH FLOOR.	0	74.3	37.3	516	2	21	0
8TH FLOOR HALLWAY.	0	74.1	37.4	516	2	16	0
Kitchen	4	74.3	41.6	669	2	16	0
CAFETERIA	6	76.4	40.6	770	2	11	0
STAIRCASE A 7TH FLOOR.	0	72.1	38.6	506	2	19	0
7TH FLOOR HALLWAY	10	72.3	40.1	860	2	19	0
Room 706	23	76.4	40.0	1016	2	21	0
Room 704	25	77.3	41.4	1143	2	20	0
Room 703	23	78.3	40.7	1126	2	11	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:


Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462571

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 14

Time: 9:15 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 6TH FLOOR	0	72.5	29.6	512	2	19	C
6TH FLOOR HALLWAY	9	72.3	36.6	691	2	21	C
Room 604	20	73.9	38.2	1041	2	19	C
Room 605	10	73.6	38.2	861	2	18	C
Room 606	0	74.1	39.3	491	2	10	C
Room 608	30	75.1	37.2	1241	2	11	C
STAIRCASE A 5TH FLOOR	0	75.3	36.3	501	2	10	C
5TH FLOOR HALLWAY	0	77.9	43.5	509	2	11	C
Room 509	21	77.3	40.2	1107	2	12	C
Room 507	19	78.8	43.2	1121	2	13	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:

Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462572

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 14

Time: 9:41 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Rm 504	0	73.6	41.1	477	2	16	C
STAIRCASE B 4TH FLOOR	0	76.5	29.6	463	2	8	C
4TH FLOOR HALLWAY	0	78.6	40.1	471	2	10	C
Rm 405	12	80.8	39.1	999	2	16	C
Rm 406	15	80.6	38.7	1011	2	20	C
Rm 410	19	80.1	42.3	1161	2	10	C
Rm 409	25	78.9	40.6	1243	2	8	C
STAIRCASE "A" 3RD FLOOR	0	75.7	33.9	429	2	7	C
Room 307	0	78.6	40.1	491	2	10	C
Room 404	0	79.3	41.6	475	2	11	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462573

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 10

Time: 10¹³ AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 2ND FLOOR	0	76.4	29.5	417	2	20	0
Room 207	15	77.7	39.0	746	2	19	0
Room 204	0	73.2	40.1	476	2	18	0
2ND FLOOR HALLWAY SOUTHSIDE	0	74.2	39.9	471	2	20	0
GYM	0	73.1	31.9	501	2	16	0
AUDITORIUM	9	74.9	30.9	861	2	16	0
1ST FLOOR LOBBY	4	73.5	31.4	601	2	21	0
Out Doors EXIT MAIN ENTRY	0	62.5	29.6	418	2	21	0
Out Doors EXT MAIN ENTRY SOUTH	0	62.5	29.6	421	2	16	0
Out Doors EXT MAIN ENTRY NORTH	0	62.5	29.6	406	2	15	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: NP

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462574

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 10

Time: 1:30 PM LOCATION: 100 Trinity Place /HS for Economics And FinancesDATE: 5-14-02 PROJECT NO: 15-19125-0291


Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Out Doors EXT MAIN ENTRY	0	66.9	29.6	541	2	31	0
Out Doors EXT MAIN ENTRY SOUTH	0	66.9	29.3	501	2	32	0
Out Doors EXT MAIN ENTRY NORTH	0	66.9	29.9	486	2	31	0
10TH FLOOR HALLWAY	0	72.3	39.9	476	2	14	0
LIBRARY	4	73.4	39.6	610	2	21	0
R 1006	6	75.1	38.6	691	2	21	0
STAIRCASE A 9TH FLOOR	0	73.9	40.6	477	2	8	0
9TH FLOOR HALLWAY	0	73.9	41.1	466	2	10	0
Rm 905	12	74.1	40.3	789	2	14	0
Rm 933	0	74.6	39.6	461	2	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:



Date:

5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462575

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 7 of 10

Time: 1:55 PM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate s (ug/m³)	TVOCs (ppm)
Rm 904	6	76.8	40.6	649	2	17	C
STAIRCASE B 8TH FLOOR	C	77.9	38.6	417	2	17	C
8TH FLOOR HALLWAY	C	77.9	38.6	501	2	11	C
Kitchen	16	76.9	38.6	801	2	10	C
CAFETERIA	11	76.9	39.1	867	2	8	C
STAIRCASE A 7TH FLOOR	C	78.1	39.1	501	2	19	C
Rm 706	22	79.2	37.7	1126	2	22	C
Room 704	C	80.1	36.6	510	2	23	C
Room 703	C	78.8	36.5	546	2	19	C
7TH FLOOR HALLWAY	C	79.9	35.1	489	2	16	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462576

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 10

Time: 2:14 PM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 6TH FLOOR.	C	76.5	24.6	427	2	21	C
6TH FLOOR. HALLWAY	C	78.3	41.1	441	2	22	C
Room 604	C	77.1	39.9	462	2	21	C
Room 605	11	76.6	39.6	665	2	11	C
Room 608	12	80.1	39.4	671	2	10	C
STAIRCASE A 6TH FLOOR.	1	79.7	40.1	557	2	16	C
5TH FLOOR ROOM 509	3	78.9	38.6	550	2	16	C
Room 606	C	77.3	38.9	462	2	16	C
5TH FLOOR HALLWAY	C	78.6	39.3	456	2	15	C
Room 507	C	79.6	39.4	440	2	14	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462577

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 9 of 10

Time: 2:27 PM LOCATION: 100 Trinity Place /IIS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate s (ug/m ³)	TVOCs (ppm)
Room 504	0	78.6	39.6	426	2	19	0
STAIRCASE B- 4TH FLOOR	0	76.2	28.6	449	2	21	0
4TH FLOOR HALLWAY.	0	79.9	38.3	500	2	11	0
Room 404	0	77.6	40.1	499	2	8	0
Room 405	0	77.5	39.9	570	2	10	0
Room 406	17	78.6	39.5	909	2	11	0
Room 410	1	78.9	36.6	546	2	11	0
Room 409	2	76.6	37.7	601	2	12	0
STAIRCASE A 3RD FLOOR	0	78.2	39.1	493	2	9	0
Room 307	0	80.1	38.1	473	2	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: NA

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462578

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 10 of 10

Time: 2:51 pm LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-14-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate s (ug/m ³)	TVOCs (ppm)
STAIRCASE B 2ND FLOOR	0	76.5	29.9	416	2	10	C
Room 207	0	79.9	39.9	440	2	16	C
Room 204	17	80.1	36.6	989	2	10	C
2ND FLOOR HALLWAY NORTHSIDE	0	73.6	38.8	426	2	19	C
Gym	0	74.4	39.9	428	2	21	C
AUDITORIUM	0	75.6	36.5	501	2	11	C
1ST FLOOR LOBBY	3	72.6	36.6	570	2	9	C
Out Doors EXT MAIN ENTRY	0	67.9	31.6	416	2	14	C
Out Doors EXT MAIN ENTRY SOUTH	0	67.9	31.6	413	2	15	C
Out Doors EXT MAIN ENTRY NORTH	0	67.9	31.6	419	2	13	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462579

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 1

Time: 5:45 pm LOCATION: 100 TRINITY PLACE DATE: 5-14-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
NORTHSIDE OF STARWELL B 6 TH FLOOR	0	73.1	35.9	422	2	26	0
SOUTHSIDE OF STARWELL B 7 TH FLOOR	0	73.6	35.9	439	2	26	0
EASTSIDE OF STARWELL B 9 TH FLOOR	0	73.2	35.6	449	2	26	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462580

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 9 of 9

Time: 7⁰⁰ AM LOCATION: COTRINITY PLACE DATE: 5-14-02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
NORTH SIDE OF STAIRWELL B 10 TH FLOOR	0	74.1	37.9	466	2	28	0
SOUTH SIDE OF STAIRWELL B 2 ND FLOOR	0	74.3	37.5	421	2	29	0
NORTHEAST OF STAIRWELL B 4 TH FLOOR	0	74.6	37.1	432	2	30	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5-14-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462581