

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page ___ of ___

Time: 7:30 AM LOCATION: 100 TRINITY PLACE DATE: 5/22/02 PROJECT NO: 15-19125-

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Out Doors INSTARwell B 4TH FLOOR	0	69.9	32.4	512	2	15	0
Out Doors INSTARwell B 3RD FLOOR	0	69.9	32.3	561	2	15	0
Out Doors INSTARwell B 8TH FLOOR	0	69.7	33.1	582	2	12	0
TIME 5:46 pm							
IN STARwell B 5TH FLOOR.	0	74.6	33.9	546	2	14	0
INSTARwell B 6TH FLOOR	0	74.6	33.6	601	2	12	0
INSTARwell B 7TH FLOOR	0	74.2	34.1	591	2	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MCI00_003462651

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 10

Time: 5:30 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Out Doors EXIT MAIN ENTRY	0	56.8	34.2	520	1	42	0
Out Doors EXIT MAIN ENTRY SOUTH	0	56.8	34.2	536	1	42	0
Out Doors EXIT MAIN ENTRY NORTH	0	56.8	34.2	539	1	42	0
10TH FLOOR HALLWAY	5	68.6	39.5	695	2	9	0
LIBRARY	0	68.7	39.5	646	2	8	0
R-1006	0	68.6	39.5	649	2	8	0
STAIRCASE A 9TH FLOOR	0	70.0	38.6	851	2	11	0
9TH FLOOR HALLWAY	0	71.1	36.5	841	2	11	0
R-915	12	71.1	36.6	909	2	17	0
Rm- 933	1	71.3	34.9	725	2	16	0
Guideline levels ASHRAE/AIHA		68 – 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462652

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 10

Time: 9:00 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room 914	0	71.3	33.7	696	2	12	0
STAIRCASE B 8TH FLOOR	0	69.3	32.2	746	2	12	0
8TH FLOOR HALLWAY	0	74.3	36.4	981	2	16	0
Kitchen	3	72.2	39.7	762	2	8	0
CAFETERIA	20	70.9	33.6	737	2	14	0
STAIRCASE A 7TH FLOOR	0	72.9	35.2	885	2	10	0
7TH FLOOR HALLWAY	0	74.2	35.7	591	2	13	0
Room 706	25	74.8	33.7	851	2	11	0
Room 704	20	74.5	33.7	848	2	10	0
Room 703	25	75.6	33.7	837	2	10	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462653

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 3 of 10

Time: 9:15 AM LOCATION: 100 Trinity Place /IIS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 6TH FLOOR	0	64.9	24.4	511	2	10	C
6TH FLOOR HALLWAY	0	76.7	32.6	838	2	6	C
Room 604	20	75.5	28.3	741	2	8	C
Room 605	12	76.8	31.9	610	2	14	C
Room 606	0	76.8	31.6	591	2	9	C
Room 608	8	76.8	31.6	818	2	11	C
STAIRCASE A 5TH FLOOR	0	78.2	32.7	1033	2	11	C
5TH FLOOR HALLWAY	0	76.5	28.1	717	2	10	C
Room 509	25	76.7	33.0	1159	2	16	C
Room 507	20	75.2	31.8	812	2	18	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462654

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 10

Time: 4:21 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Rm 504	0	78.8	30.7	905	2	16	0
STAIRCASE B 4TH FLOOR	0	68.6	24.3	526	2	16	0
4TH FLOOR HALLWAY	0	72.3	32.6	546	2	8	0
Rm 405	25	74.3	29.9	828	2	8	0
Rm 406	3	74.6	30.1	1042	2	9	0
Rm 410	12	78.5	32.5	910	2	13	0
Rm 409	17	78.3	32.5	965	2	11	0
STAIRCASE "A" 3RD FLOOR	0	78.0	32.1	475	2	8	0
Room 307	0	78.6	31.1	924	2	10	0
Room 404	0	78.3	29.9	601	2	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462655

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT


Page 5 of 10

Time: 9:36 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 2ND FLOOR	0	66.9	33.3	5216	2	14	C
Room 207	25	77.8	30.1	969	2	11	C
Room 204	0	77.6	30.2	940	2	8	C
2ND FLOOR HALLWAY SOUTH SIDE	C	77.3	30.3	741	2	10	C
GIM	0	76.9	28.6	641	2	11	C
AUDITORIUM	7	71.9	27.1	703	2	13	C
1ST FLOOR LOBBY	7	71.6	27.0	652	2	11	C
Out Doors EXT MAIN ENTRY	0	61.6	26.8	571	1	41	C
Out Doors EXT MAIN ENTRY SOUTH	0	61.6	26.8	591	1	41	C
Out Doors EXT MAIN ENTRY NORTH	3	61.6	26.8	560	1	41	C
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: 

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462656

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 10

Time: 11:30 AM LOCATION: 100 Trinity Place / IIS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Out Doors EXT MAIN ENTRY	0	63.5	38.9	601	1	44	0
Out Doors EXT MAIN ENTRY SOUTH	0	63.5	39.1	555	1	44	0
Out Doors EXT MAIN ENTRY NORTH	0	63.5	39.4	610	1	44	0
10TH FLOOR HALLWAY	2	71.6	39.3	686	1	13	0
LIBRARY	6	71.3	39.1	710	1	12	0
R 1006	0	69.9	39.1	586	1	16	0
STAIRCASE-A 9TH FLOOR	0	70.6	38.6	599	1	10	0
9TH FLOOR HALLWAY	0	71.7	36.9	601	1	10	0
Rm 915	7	71.6	36.8	746	1	11	0
Rm 933	2	71.9	36.5	691	1	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462657

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 7 of 10

Time: 11:50 AM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Rm 904	22	71.6	34.1	1012	2	16	0
STAIRCASE B 8TH FLOOR	0	72.3	34.6	510	2	11	0
8TH FLOOR HALLWAY	0	74.5	34.3	506	2	11	0
Kitchen	3	72.4	35.1	621	2	8	0
CAFETERIA	10	70.1	36.1	747	2	10	0
STAIRCASE A 7TH FLOOR	0	73.1	34.7	501	2	7	0
Room 706	20	75.1	34.3	989	2	9	0
Room 704	25	75.6	34.1	1026	2	10	0
Room 703	30	75.7	34.3	1261	2	10	0
7TH FLOOR HALLWAY	0	73.4	34.7	601	2	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: 

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462658

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 10

Time: 12¹⁰pm LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5-22-02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 6TH FLOOR	0	70.1	25.6	527	2	12	0
6TH FLOOR HALLWAY	0	74.1	33.1	591	2	11	0
Room 604	25	75.9	28.9	1266	2	7	0
Room 605	29	77.1	32.9	1301	2	16	0
Room 608	31	77.3	34.1	1161	2	16	0
STAIRCASE A 6TH FLOOR	0	74.6	33.6	510	2	11	0
5TH FLOOR ROOM 509	0	77.6	33.6	609	2	14	0
Room 606	26	77.8	32.3	1019	2	13	0
5TH FLOOR HALLWAY	0	77.1	29.1	641	2	17	0
Room 507	0	76.6	32.9	581	2	8	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: N/A

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5-22-02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462659

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 9 of 10

Time: 12³⁶pm LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room 504	3	79.1	31.6	641	2	11	0
STAIRCASE B - 4TH FLOOR	0	70.9	25.9	591	2	9	0
4TH FLOOR HALLWAY	0	73.6	33.1	501	2	13	0
Room 404	26	78.9	36.3	1147	2	11	0
Room 405	30	75.6	29.9	1241	2	10	0
Room 406	0	75.6	30.3	551	2	16	0
Room 410	16	79.6	33.1	1021	2	15	0
Room 409	0	79.2	33.1	601	2	8	0
STAIRCASE A 3RD FLOOR	0	80.1	33.9	520	2	8	0
Room 307	0	79.3	32.1	499	2	7	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462660

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 10 of 10

Time: 1:00 PM LOCATION: 100 Trinity Place /HS for Economics And Finances DATE: 5/22/02 PROJECT NO: 15-19125-0291

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRCASE B 2ND FLOOR	0	70.6	25.7	501	1	14	0
Room 207	0	78.6	31.9	926	1	8	0
Room 204	10	78.3	31.3	846	1	10	0
2ND FLOOR HALLWAY NORTH SIDE	0	78.3	31.6	649	1	11	0
Gym	0	77.1	28.9	710	1	16	0
AUDITORIUM	10	72.1	28.3	751	1	17	0
1ST FLOOR LOBBY	6	71.9	27.6	761	1	15	0
Out Doors EXT MAIN ENTRY	0	68.1	24.1	529	1	51	0
Out Doors EXT MAIN ENTRY SOUTH	0	68.1	24.6	541	1	51	0
Out Doors EXT MAIN ENTRY NORTH	2	68.3	24.3	515	1	53	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 5/22/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003462661