

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 03-18-02

CLIENT: NYC BOE

PROJECT ADDRESS: M833/100 Trinity Place,
NY, NY 10006

PROJECT NO: 41617-0563

SAMPLED BY: Chacko Mathew

SAMPLE DATE: 03-15-02

DATE RECEIVED: 03-16-02

DATE ANALYZED: 03-16-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9728	Classroom/Office Room 1002 (all)	<3.0	3.0
02	9728	Ninth Floor by Center Floor	<9.0	9.0
03	9728	Cafeteria Floor by Wall 3 Floor	<9.0	9.0
04	9728	Seventh Floor Hallway by Rm 706 Floor	<9.0	9.0
05	9728	6th Floor Classroom 607 Floor	<9.0	9.0
06	9728	5th Floor Hallway by Elevator Floor	<9.0	9.0
07	9728	4th Floor Classroom 402 Floor	<9.0	9.0
08	9728	3rd Floor Hallway by Rm 305 Floor	<9.0	9.0
09	9728	Auditorium by Stage Floor	<9.0	9.0
10	9728	Outside by Main Entrance Lobby Floor	<9.0	9.0
11	9728	Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CONFIDENTIAL,

CITY_21MC100_003463297

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: IL

REPORT PREPARED BY: J. M. O.

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: W. S.

LABORATORY DIRECTOR: M. C.

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).

CONFIDENTIAL,

CITY_21MC100_003463298

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008