

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 04-29-02
CLIENT: NYC BOE
PROJECT ADDRESS: M477/345 Chambers Street
Bronx, NY 10007
PROJECT NO: 41617-0563
SAMPLED BY: C. Mathew
SAMPLE DATE: 04-27-02
DATE RECEIVED: 04-27-02
DATE ANALYZED: 04-27-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9788	Window Sill Office Space Rm 911	<2.8	2.8
02	9788	Floor 9th Floor Hallway by Room 920	<9.0	9.0
03	9788	Floor 8th Floor Cafeteria by Counters	<9.0	9.0
04	9788	Floor Seventh Floor Hallway by Room 704A	<9.0	9.0
05	9788	Floor Sixth Floor Classroom 606	<9.0	9.0
06	9788	Floor 5th Floor Hallway by Room 504	<9.0	9.0
07	9788	Floor 4th Floor Classroom 405	<9.0	9.0
08	9788	Floor 3rd Floor Hallway by Rm 307	<9.0	9.0
09	9788	Floor Main Entrance Lobby by Room 105	<9.0	9.0
10	9788	Floor Inside Auditorium by Stage	<9.0	9.0
11	9788	Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CONFIDENTIAL,

CITY_21MC100_003463343

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: WCH

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).

CONFIDENTIAL,

CITY_21MC100_003463344

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008