NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 05-30-02

CLIENT: NYC BOE

PROJECT ADDRESS: M833 / 100 Trinity Place
New York, NY 10006

PROJECT NO: 41617-0563

SAMPLED BY: C. Mathew

SAMPLE DATE: 05-25-02
DATE RECEIVED: 05-25-02
DATE ANALYZED: 05-25-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
01	9829	Window Sill North Floor Office 904	<2.6	2.6
02	9829	Floor 9th Floor Hallway by Elevator	<9.0	9.0
03	9829	Floor Cafeteria by Entrance	<9.0	9.0
04	9829	Floor 7th Floor Hallway by Rm 707	<9.0	9.0
05	9829	Floor 6th Floor Classroom 606	<9.0	9.0
06	9829	Floor 5th Floor Hallway by 505	<9.0	9.0
07	9829	Floor 4th Floor Classroom 407	<9.0	9.0
08	9829	Floor 3rd Floor Halway by Rm 313	<9.0	9.0
09	9829	Floor Main Entrance Lobby by Rm 105	<9.0	9.0
10	9829	Floor Auditorium 1 by Middle of Right Isle	<9.0	9.0
11	9829	Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3:
Blank units are in µg

CONFIDENTIAL, CITY_21MC100_003463352
SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____

REPORT PREPARED BY: _____

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____

LABORATORY DIRECTOR: _____

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).