

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 06-17-02
CLIENT: NYC BOE
PROJECT ADDRESS: M833 / 100 Trinity Place
New York, NY 10006
PROJECT NO: 41617-0563
SAMPLED BY: C. Mathew
SAMPLE DATE: 06-15-02
DATE RECEIVED: 06-15-02
DATE ANALYZED: 06-15-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	9854	9th Floor Office Rm 904 Window Sill	<2.6	2.6
02	9854	9th Floor Hallway by Rm 903 Floor	<9.0	9.0
03	9854	8th Floor Cafeteria by Entrance Floor	16.5	9.0
04	9854	7th Floor Hallway by Rm 705 Floor	<9.0	9.0
05	9854	6th Floor Classroom 604 Floor	<9.0	9.0
06	9854	5th Floor Hallway by Rm 507 Floor	<9.0	9.0
07	9854	4th Floor Classroom 406 Floor	9.6	9.0
08	9854	3rd Floor Hallway by 305 Floor	<9.0	9.0
09	9854	1st Floor Lobby by Rm 102 Floor	11.6	9.0
10	9854	Auditorium by Entrance Floor	11.7	9.0
11	9854	Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CONFIDENTIAL,

CITY_21MC100_003463393

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: TC

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

CONFIDENTIAL,

CITY_21MC100_003463394

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008