

ATC ASSOCIATES, INC.

Page 1 of 1

TIME 2:30pm

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 03/05/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
MAIN ENTRANCE		49.8	21.1	365	2	79	0.0
NORTH OF MAIN ENTRANCE		46.9	21.5	349	5 ppm	72	0.0
SOUTH OF MAIN ENTRANCE		39.0	21.6	317	4	68	0.0
Hallway 14th Floor		57.8	30.9	535	0	44	0.0
KITCHEN 14 FL	3	62.2	30.4	550	0	23	0.0
STAIRWELL A Room 1406	0	38.7	21.5	313	0	8	0.0
Hallway 13th Floor	0	65.5	23.7	571	1	6	0
STAIRWELL 13th Floor A	3	66.3	22.5	547	1	10	0
12th Floor Hallway	15	67.6	23.6	711	1	15	0
Room 1206	4	68.0	23.3	702	1	10	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Frank Daddapanu Date: 03/05/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463542

NYC-WTC_000180149

Page 2 of 2

TIME

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 03/05/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Room #1205	3	68.9	23.9	771	1	8	0.0
Room #1203	2	69.0	23.5	766	1	12	0.0
Room #1215	8	70.3	22.2	635	1	9	0.0
Hallway opposite Rm 1215	0	70.2	21.9	663	1	12	0.0
STAIRWELL 12th Floor	0	69.7	21.6	654	1	13	0.0
Hallway 11th Floor	0	69.1	22.3	759	2	9	0.0
Room #1109	3	69.9	21.7	683	1	9	0.0
Room #1105	1	70.6	21.4	662	1	9	0.0
Room #1106	1	71.3	20.4	681	1	11	0.0
11th Floor STAIRWELL A	1	70.2	20.9	688	1	17	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Pran D. Dalapati Date: 02/05/07

ATC ASSOCIATES, INC.

Page 3 of 4

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE _____

PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m ³)	TVOCs (ppm)
Room #1003	1	70.4	20.6	669	2	18	0.0
Hallway By Elevators	1	70.7	20.3	622	1	15	0.0
Room #1009	0	70.6	19.5	549	1	7	0.0
Room #1015	3	70.8	20.1	654	1	9	0.0
Hallway 10th Floor	0	70.6	20.4	613	1	13	0.0
STAIRwell B on Floor	0	70.1	20.1	617	1	10	0.0
Hallway By Room #915	0	69.7	20.0	603	1	9	0.0
Room #915	0	69.5	19.8	605	1	8	0.0
Room #906	0	68.5	18.6	529	1	7	0.0
Room #903	1	69.4	18.8	531	1	7	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Pranil Daddapuri Date: 03/05/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463544

ATC ASSOCIATES, INC.

Page 4 of 4

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE _____

PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
STAIRwell B 8th Floor	0	69.0	19.2	532	1	8	0.0
Hallway 8th Floor	0	68.5	19.6	542	1	6	0.0
Room #815	1	69.3	20.1	636	1	6	0.0
Room #805	2	69.5	19.6	579	1	7	0.0
Room #803	1	71.8	20.2	544	2	6	0.0
Hallway Elev 8th Floor	1	71.2	19.9	546	2	6	0.0
STAIRwell B 7th Floor	0	70.2	20.0	599	2	16	0.2
Hallway By Room #715	0	69.8	19.4	523	1	8	0.0
Room #715	0	69.4	19.2	492	2	6	0.0
Room #713	0	69.6	18.9	478	2	5	0.0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Frank DaddapanDate: 04/05/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463545

ATC ASSOCIATES, INC.

Page 5 of 5

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE _____

PROJECT NO. 19125-0293

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Room #703	0	69.5	19.4	515	1	6	0.0
Room #705	4	70.4	20.6	645	1	10	0.0
Hallway 7th Floor Elev	2	70.4	20.2	657	1	5	0.0
Room #702	3	70.2	20.3	680	1	12	0.0
STAIR A 7th Floor	0	70.1	20.1	600	1	8	0.0
Hallway 6th Floor Elev	1	69.1	20.9	611	2	6	0.0
Room #609	1	70.1	20.1	541	2	5	0.0
Hallway		70.3	21.1	671	2	5	0.0
Room #613	4	70.1	21.0	592	1	4	0.0
STAIR W 6th Floor	0	69.9	20.1	538	1	5	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapanu Date: 03/05/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MCI00_003463546

ATC ASSOCIATES, INC.

Page 6 of

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICEDATE _____ PROJECT NO. 19125-02951

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(µg/m³)	TVOCs (ppm)
5th Floor Elev Hallway	0	68.9	19.6	553	2	9	0.0
Room #415	0	69.3	18.9	467	1	6	0.0
4th Floor Hallway	0	70.3	19.2	510	1	5	0.0
Room #404	0	69.5	19.1	489	1	5	0.0
Room #409	2	70.0	19.1	485	1	4	0.0
Room #403	12	70.1	21.2	705	1	7	0.0
STAIRWELL A 4th Floor	0	70.2	21.3	867	1	5	0.0
STAIRWELL A 3rd Floor	2	69.9	20.6	702	1	15	0.0
Room #305	12	70.7	20.2	656	1	7	0.0
Hallway 3rd Floor	0	70.9	20.6	658	1	6	0.0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Frank DeLapina Date: 03/05/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463547

ATC ASSOCIATES, INC.

Page 7 of

TIME _____

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 03/05/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Room #315	1	69.6	18.8	502	2	5	0.0
STARWELL A 2nd Floor	2	69.8	20.4	639	2	4	0.0
Hallway 2nd floor	0	70.4	20.2	674	1	6	0.0
Room #206	0	71.3	19.6	789	1	6	0.0
Room #205	3	71.3	19.5	593	1	8	0.0
Hallway BSM	0	67.9	31.1	709	2	22	0.0
BSM Gym	10	70.6	31.3	891	2	18	0.0
MAIN ENTRANCE		44.2	16.6	355	4	52	0.0
NORTH OF MAIN ENTRANCE		45.6	16.9	359	4	49	0.0
SOUTH OF MAIN ENTRANCE		45.3	17.8	365	3	33	0.0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 04/05/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463548