

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 14

Time: 10:40 AM LOCATION: 90 Trinity Place /HS for Economics And Finances DATE: 03/08/2002 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
OUTSIDE MAIN ENTRANCE		51.5	41.2	389	4	125	0
NORTH OF MAIN ENTRANCE		48.0	47.3	384	3	119	0
SOUTH OF MAIN ENTRANCE		50.6	49.7	413	3	138	0
14th FLOOR Hallway ELEVATOR AREA	2	66.1	44.8	584	1	45	0
14th FLOOR KITCHEN	3	67.1	42.3	617	2	44	0
14th FLOOR CAFETERIA Room # 1406	75	67.6	41.5	963	2	46	0
STAIRWELL A 14th FLOOR TO 13th FLOOR	2	67.9	38.6	635	2	44	0
13th FLOOR Hallway ELEVATOR AREA	0	68.2	37.1	571	2	45	0
13th FLOOR Room # 1306	20	68.1	37.3	541	2	60	0
13th FLOOR Room # 1303	1	67.9	36.1	525	2	38	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463590

ATC ASSOCIATES, INC.

Page 2 of 14

INDOOR AIR QUALITY FIELD REPORT

Time: 10:55 AM LOCATION: 90 Trinity Place /HS for Economics And Finance DATE: 03/08/2002 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
13th Floor Room # 1307	0	68.1	35.9	490	2	51	0
13th Floor Stairwell A TO 12th Floor	2	68.5	36.3	575	2	46	0
12th Floor Hallway ELEVATOR AREA	1	68.7	36.4	629	2	47	0
12th Floor Room # 1203	3	69.0	37.1	711	2	43	0
12th Floor Room # 1206	25	69.3	37.2	671	2	54	0
12th Floor Room # 1215	23	69.5	38.2	900	2	50	0
12th Floor Stairwell TO 11th Floor	0	69.2	35.2	612	2	39	0
11th Floor Room # 1109	27	69.6	37.2	873	2	43	0
11th Floor Room # 1105	19	70.0	36.9	822	2	48	0
11th Floor Room # 1106	28	70.4	36.2	862	2	50	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad DoddapaneniDate: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463591

ATC ASSOCIATES, INC.

Page 3 of 14

INDOOR AIR QUALITY FIELD REPORT

Time: 11:07 AM LOCATION: 90 Trinity Place /HS for ~~Economics And Finance~~ ^{LEADERSHIP PUBLIC SERVICES} DATE: 03/08/2002 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
10th Floor Room # 1015 Room # 1015	24	70.0	35.7	760	2	48.1	0
10th Floor Room # 1009	25	70.2	36.3	883	2	52.1	0
10th Floor Room # 1005	25	70.4	36.5	997	2	53.1	0
10th Floor Stairwell B to 9th Floor	8	70.4	35.7	805	2	54.1	0
9th Floor Hallway Elevator Area	0	69.8	33.9	611	2	48.1	0
9th Floor Room # 906	4	69.5	33.7	528	2	49.1	0
9th Floor Room # 905	30	70.0	36.6	847	2	46.1	0
9th Floor Room # 909	1	69.4	34.6	623	2	43.1	0
8th Floor Hallway	8	68.9	34.7	689	2	42.1	0
8th Floor Stairwell to 9th Floor	1	69.3	34.4	579	2	41.1	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463592

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 14

LEADERSHIP PUBLIC SERVICES
Economics And Finances

Time: 11:20 LOCATION: 90 Trinity Place /HS for DATE: 03/08/2002 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
8th Floor Room # 805	20	70.2	37.0	900	2	52	0
8th Floor Room # 809	23	70.4	37.1	827	2	45	0
8th Floor Stairwell A TO 7th Floor	1	70.2	34.8	675	2	42	0
7th Floor Hallway ELEVATOR AREA	8	70.5	34.4	672	2	43	0
7th Floor Room # 702 ELEVATOR AREA	4	70.6	34.3	649	2	44	0
7th Floor Room # 705	5	70.4	33.9	638	2	39	0
7th Floor Room # 713	0	70.5	33.6	568	2	42	0
7th Floor Room # 715	6	70.8	33.9	609	2	41	0
6th Floor Hallway BY Room # 615	2	70.8	34.1	692	2	37	0
6th Floor Room # 613	4	70.9	34.0	658	2	34	0
Guideline levels ASHRAE/AIHA		68 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463593

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 14

LEADERSHIP PUBLIC SERVICES
Economics And Finance

Time: 12:35 LOCATION: 90 Trinity Place /HS for ~~Economics And Finance~~ DATE: 03/08/2002 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
6th Floor Room # 609	5	70.6	33.6	685	2	33	0
6th Floor Room # 615	2	70.5	33.9	623	2	36	0
6th Floor STAIRWELL A TO 5th Floor	1	70.3	33.5	638	2	43	0
5th Floor Hallway ELEVATOR AREA	0	70.0	33.7	560	2	45	0
5th Floor Room # 515	1	70.2	34.5	586	2	45	0
5th Floor Room # 509	2	70.0	33.8	542	2	47	0
5th Floor Room # 506	23	70.1	35.0	662	2	48	0
5th Floor Room # 503	0	69.6	33.7	529	2	47	0
4th Floor Hallway ELEVATOR AREA	0	69.8	34.1	593	2	45	0
4th Floor Room # 404	19	70.1	35.4	739	2	42	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463594

ATC ASSOCIATES, INC.

Page 6 of 14

INDOOR AIR QUALITY FIELD REPORT

LEADERSHIP PUBLIC SERVICES

Time: 11:40 AM LOCATION: 90 Trinity Place /HS for Economics And Finances DATE: 03/08/2002 PROJECT NO: 15-19125-029D

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
4th Floor Room # 404	19	70.5	35.3	725	2	47	0
4th Floor Room # 409	0	70.8	34.7	672	2	43	0
4th Floor Stairwell A to 3rd Floor	0	70.5	34.3	618	2	45	0
3rd Floor Hallway Elevator Area	0	70.4	33.8	571	2	44	0
3rd Floor Room # 309	0	70.3	34.1	523	2	42	0
Hallway in front of 3rd Floor Room # 315	0	70.4	34.4	658	2	42	0
3rd Floor Room # 315 Stairwell B	0	70.6	33.6	714	2	41	0
3rd Floor Hallway near Room # 306	0	70.4	33.4	561	2	43	0
3rd Floor Stairwell to 2nd Floor A	0	70.7	34.2	710	2	40	0
2nd Floor Hallway Elevator Area	0	70.5	33.5	571	2	46	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463595

ATC ASSOCIATES, INC.

Page 7 of 14

INDOOR AIR QUALITY FIELD REPORT

LEADERSHIP PUBLIC SERVICES

Time: 12:05 LOCATION: 90 Trinity Place /HS for Economics And Finance DATE: 03/08/2002 PROJECT NO: 15-19125-029D

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
2nd Floor Room # 205	0	69.7	33.4	578	2	45	0
2nd Floor Room # 206 NORTH SIDE	0	70.4	33.2	486	2	44	0
2nd Floor Room # 206 EAST SIDE	0	70.6	33.2	504	2	43	0
2nd Floor Room # 206 SOUTH SIDE	0	70.1	33.4	492	2	46	0
2nd Floor Stairwell to 1st Floor	0	70.6	33.0	552	2	41	0
Basement Hallway Gym Area	0	70.5	39.8	657	2	40	0
Basement Gym	0	72.2	42.9	630	2	34	0
Outside Main Entrance	0	54.1	36.1	445	3	123	0
Outside North of Main Entrance		49.5	38.4	428	5	121	0
Outside South of Main Entrance		51.7	44.9	432	3	164	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463596

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 8 of 14

Time: 2:35 PM ⁹⁰ LOCATION: ~~100~~ ⁹⁰ Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
MAIN ENTRANCE - OUTDOORS		55.2	39.1	415	2	137	0
OUTDOORS SOUTH OF MAIN ENTRANCE		54.2	38.6	398	2	122	0
NORTH OF MAIN ENTRANCE OUTDOORS		52.0	41.7	396	2	120	0
14 th FLOOR Hallway	1	66.0	45.7	588	2	40	0
14 th FLOOR CAFETERIA	1	66.5	46.3	552	1	34	0
14 th FLOOR Room # 1403	20	67.3	48.1	868	2	39	0
STAIRWELL A 14 th FLOOR	5	68.7	44.7	706	2	41	0
Hallway 13 th FLOOR	0	68.8	40.1	677	2	48	0
STAIRWELL A 13 th FLOOR	1	68.9	38.8	698	2	45	0
STAIRWELL A 12 th FLOOR	8	69.6	40.6	734	2	59	0
Guideline levels ASHRAE/AIHA		68-75°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463597

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 9 of 14

Time: 2:50 PM LOCATION: 90 100 Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room # 1206	3	69.8	39.4	692	2	57	0
Room # 1205	2	70.4	39.1	679	2	46	0
Room # 1203	2	70.5	39.6	789	2	44	0
Room # 1205	2	70.8	38.0	650	2	45	0
Hallway By Room # 1215	1	70.7	37.7	663	2	48	0
Hallway By Room # 1203	1	70.8	37.1	614	2	46	0
STAIRWELL 'A' 11th Floor	2	70.4	37.8	770	2	51	0
Hallway By Room # 1103	1	70.7	36.9	716	2	44	0
Room # 1105	1	70.8	36.6	620	2	47	0
Hallway OUTSIDE Room 1105	1	70.9	36.7	698	2	49	0
Guideline levels ASHRAE/AIHA		69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad DoddapaneniDate: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463598

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 0 of 14

Time: 2:55 PM 90
 LOCATION: 100 Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room # 1109	7	70.9	36.5	709	2	44	0
Room # 1115	6	70.6	35.4	578	2	43	0
STAIRWELL B 11th Floor	0	70.5	35.8	589	2	44	0
STAIRWELL B 10th Fl	0	70.2	35.6	683	2	47	0
Room # 1015	7	70.5	36.9	678	2	50	0
Room # 1005	7	70.7	36.3	653	2	52	0
Hallway OUTSIDE Room # 1005	0	70.8	36.6	622	2	51	0
Hallway OUTSIDE 1003	0	70.7	35.8	593	2	48	0
STAIRWELL 'A' 10th Fl	0	70.3	35.3	610	2	51	0
STAIRWELL 'A' 9th Floor	0	70.7	35.9	674	2	61	0
Guideline levels ASHRAE/AIHA		69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad Doddapaneni Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463599

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 11 of 14

Time: 3:05 PM ⁹⁰ LOCATION: 100 Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room # 909	0	70.3	36.0	621	2	43	0
Room # 915	1	70.3	36.2	678	2	44	0
Hallway OUTSIDE Room # 915	0	70.4	36.0	696	2	43	0
STAIRWELL 'B' 9th Floor	0	70.2	35.3	596	2	45	0
STAIRWELL 'B' 8th Floor	0	70.0	35.4	634	2	44	0
Room # 815	8	70.3	35.5	645	2	43	0
Hallway OUTSIDE Rm # 815	0	70.5	35.6	626	1	47	0
Room # 809	1	70.5	35.4	590	1	45	0
Room # 805	1	70.7	35.6	569	2	45	0
Room # 803	0	70.8	35.3	562	2	40	0
Guideline levels ASHRAE/AIHA		69 – 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad DoddapaneniDate: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463600

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 14

Time: 3:20 PM LOCATION: ⁹⁰~~100~~ Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
STAIRwell 'A' 7th floor	0	70.9	35.7	611	1	41	0
7th Floor Hallway By Room # 702	0	70.6	34.8	602	2	42	0
Room # 702	5	71.2	35.6	697	2	45	0
Room # 703	1	71.1	35.0	645	2	43	0
Room # 705	1	70.9	34.6	607	2	36	0
Room # 711	3	70.7	34.4	556	2	42	0
Room # 713	0	70.9	34.2	536	2	41	0
Hallway OUTSIDE Room # 711	2	71.0	34.5	534	2	42	0
STAIRWELL 'B' 7th floor	0	70.9	34.7	580	2	39	0
Hallway 6th floor By Room # 615	1	70.7	34.1	522	2	35	0
Guideline levels ASHRAE/AIHA		69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni / Prasad DoddapaneniDate: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463601

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 14

Time: 3:30 PM LOCATION: ⁹⁰~~100~~ Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Room # 315	1	70.6	35.5	539	2	50	0
Hallway OUTSIDE Room # 607	0	70.6	34.3	579	2	33	0
Hallway Elev Area 6 FL	0	70.2	34.1	532	2	37	0
STAIRWELL 'A' 5 FL	1	70.7	34.7	562	2	39	0
Hallway 5th FL Elevator Area	1	70.4	34.1	508	2	43	0
Hallway 5th Floor Room # 515	0	70.5	34.2	462	2	41	0
STAIR CASE 'A' 5th Floor	0	70.6	34.7	513	2	40	0
STAIR CASE 'A' 4th Floor	0	70.4	35.0	547	2	41	0
Hallway By Room # 415	0	70.5	35.0	492	2	44	0
Room # 404	0	71.0	34.4	460	2	44	0
Guideline levels ASHRAE/AIHA		69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad Doddapaneni

Date: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463602

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 14 of 14

Time: 3:45 PM ⁹⁰ LOCATION: ~~100~~ Trinity Place/HS for Leadership And Public Services DATE: 03/08/02 PROJECT NO: 15-19125-0290

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
^{Elev AREA} 3rd Floor Hallway	1	71.1	34.1	511	2	42	0
^{Room # 301} 3rd Floor Hallway	0	71.0	34.2	490	2	47	0
2nd Floor Hallway	0	70.9	34.0	513	2	43	0
2nd Floor Room # 206	0	71.3	34.3	504	2	49	0
STAIRWELL TO BSMT from 2nd floor	0	71.0	34.1	499	2	41	0
Hallway OUTSIDE Gym	0	70.9	36.0	709	2	37	0
BASEMENT Gym	0	72.2	44.3	761	2	35	0
^{OUTDOORS} MAIN ENTRANCE		62.8	33.4	470	3	133	0
^{OUTDOORS} NORTH OF MAIN ENTRANCE		61.0	33.5	438	4	129	0
^{OUTDOORS} SOUTH OF MAIN ENTRANCE		55.0	34.1	442	4	131	0
Guideline levels ASHRAE/AIHA		69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Prasad Doddapaneni/ Prasad DoddapaneniDate: 03/08/02

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

CONFIDENTIAL,

CITY_21MC100_003463603