

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122 Phone: (212) 477-8941

Received: 2/6/02 8:10:00 PM

ATC Group #: 6582

Analysis Date: 2/7/02

Project: NYC-BOE PS 234M Project#: 14584-1823
292 Greenwich St., New York, NY**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 6582 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
04 6582 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
05 6582 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
06 6582 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
07 6582 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
08 6582 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
09 6582 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
10 6582 -8	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003467767

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 2/6/02 8:10:00 PM

ATC Group #: 6582

Analysis Date: 2/7/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC-BOE PS 234M Project#: 14584-1823
292 Greenwich St., New York, NY


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
11 6582 -9	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 6582 -10	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
13 6582 -11	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 6582 -12	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
15 6582 -13	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
16 6582 -14	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
17 6582 -15	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CONFIDENTIAL,

CITY_21MC100_003467768

SUBJECT TO PROTECTIVE ORDER NO. 2, SEPT. 2008