NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1920
Lab Group #:	6852	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	12	**Grid Opening Size:**	0.01124
Client Sample #:	12	**Area Examined:**	0.04496 mm²
GRID BOX:	~~2K~~ 3K	**Magnification:**	20,000
GRID ID:	~~2~~ 3K	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	2/28/02

Analysis Performed By: RP
ROMAN PEYSAKHOV

GO		Structure	Structure Type				Length		ID of Structure N or √				EDS
No	Coord	No	F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	(Nonadd Elements)
2K 1	J 2	NSD											
2	Q 2	1		√				√	√				
3	Q-7	NSD											
4	L 2	4											
3K													

Struct = > 0.5µ >5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					