

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Fred Burkhardt

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 9/16/02

4:30:00 PM

ATC Group #: 8844

Analysis Date: 9/18/02

Project: DEP Clean-up Project #: 22906-0002

125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
04 8844 -1	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
05 8844 -2	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
06 8844 -3	2500.00	0.0450	0	None Detected	0	0	0.0034	<22.24	<0.0034	
07 8844 -4	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
08 8844 -5	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
09 8844 -6	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
10 8844 -7	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Fred Burkhardt

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 9/16/02

4:30:00 PM

ATC Group #: 8844

Analysis Date: 9/18/02

Project: DEP Clean-up Project #: 22906-0002


125 Cedar Street, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
11 8844 -8	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
12 8844 -9	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
13 8844 -10	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
14 8844 -11	2300.00	0.0450	0	CHRYSTOLE	1	1	0.0037	44.48	0.0074	
15 8844 -12	2400.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
16 8844 -13	2390.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
17 8844 -14	2390.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
18 8844 -15	2380.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	
19 8844 -16	2370.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for: NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Fred Burkhardt
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 9/16/02 4:30:00 PM
 ATC Group #: 8844
 Analysis Date: 9/18/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
20 8844 -17	2370.00	0.0450	0	CHRYSTILE	1	1	0.0036	44.48	0.0072
21 8844 -18	2350.00	0.0450	0	None Detected	0	0	0.0036	<22.24	<0.0036


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879