

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Fred Burkhardt

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 9/20/02

8:00:00 AM

ATC Group #: 8865

Analysis Date: 9/22/02

Project: DEP Clean-up Project #: 22906-0002

125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
01 8865 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
02 8865 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
03 8865 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
04 8865 -4	1804.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 8865 -5	1804.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879