

10/10/2002 07:45 FAX 212 353 8306

ATC

003

Attn: Benjamin Sallemi
ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Received: 10/8/02 11:10:00 AM

ATC Group #: 8943

Analysis Date: 10/9/02

Project: DEP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
12N-08 8943 -8	3800.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 1 Structures
12N-09 8943 -9	3790.00	0.1236	5	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 5 Structures
12N-10 8943 -10	3780.00	0.1236	0	None Detected	0	0	0.0008	<8.09	<0.0008	
12SW-11	3760.00	0.1236	3	None Detected	0	0	0.0008	<8.09	<0.0008	Cellulose - 3 Structures