

10/11/2002 16:37 FAX 212 353 8306

ATC

1002

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Benjamin Sallemi
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
PH-01 8943 -1	3850.00	0.1236	3	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
PH-02 8943 -2	3840.00	0.1236	4	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 4 Structures
PH-03 8943 -3	3830.00	0.1236	3	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
PH-04 8943 -4	3820.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
PH-05 8943 -5	3810.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-06 8943 -6	3820.00	0.1236	1	None Detected	0	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-07 8943 -7	3810.00	0.1236	0	None Detected	0	0	0.0008	<8.09	<0.0008

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for: NVLAP PLM/TEM #101157-0, NY State ELAP #10879

Page 1 of 6

CITY_21MC100_009369437

10/11/2002 16:38 FAX 212 353 8306

ATC

003

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street

New York NY 10010

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

Received: 10/8/02 11:10:00 AM

ATC Group #: 8943

Analysis Date: 10/9/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
12N-08 8943 -8	3800.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12N-09 8943 -9	3790.00	0.1236	5	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 5 Structures
12N-10 8943 -10	3780.00	0.1236	0	None Detected	0 0	0.0008	<8.09	<0.0008
12SW-11 8943 -11	3760.00	0.1236	3	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
12SW-12 8943 -12	3750.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12SW-13 8943 -13	3740.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
12SE-14 8943 -14	3730.00	0.1236	5	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 4 Structures, Gypsum - 1 Structure
12SE-15 8943 -15	3720.00	0.1236	1	None Detected	0 0	0.0008	<8.09	<0.0008 Cellulose - 3 Structures
12SE-16 8943 -16	3710.00	0.1236	0	None Detected	0 0	0.0008	<8.09	<0.0008

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #01187-0, NY State ELAP #16079

Page 2 of 6

CITY_21MC100_009369438

10/11/2002 16:38 FAX 212 353 8308

ATC

004

Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

Received: 10/8/02

11:10:00 AM

ATC Group #: 8943

Analysis Date: 10/9/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
12SE-17 8943 -17	3700.00	0.1236	4	None Detected	0	0.0008	<8.09	<0.0008 Cellulose - 4 Structures
12SE-18 8943 -18	3690.00	0.1236	1	None Detected	0	0.0008	<8.09	<0.0008 Cellulose - 1 Structures
11N-19 8943 -19	3660.00	0.1236	0	None Detected	0	0.0009	<8.09	<0.0009
11N-20 8943 -20	3650.00	0.1236	2	None Detected	0	0.0009	<8.09	<0.0009 Cellulose - 1 Structures
11N-21 8943 -21	3640.00	0.1236	3	None Detected	0	0.0009	<8.09	<0.0009 Cellulose - 3 Structure
11N-22 8943 -22	3630.00	0.1236	1	None Detected	0	0.0009	<8.09	<0.0009 Cellulose - 1 Structures
11N-23 8943 -23	3620.00	0.1236	5	None Detected	0	0.0009	<8.09	<0.0009 Cellulose - 3 Structures, Gypsum - 2 Structure
11S-24 8943 -24	3630.00	0.1236	0	None Detected	0	0.0009	<8.09	<0.0009
11S-25 8943 -25	3620.00	0.1236	2	None Detected	0	0.0009	<8.09	<0.0009 Cellulose - 2 Structures

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10870

Page 3 of 6

CITY_21MC100_009369439

10/11/2002, 18:39 FAX 212 353 8308

ATC

005

Attn: Benjamin Sallami
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
11S-26 8943 -26	3610.00	0.1236	1	None Detected	0 0	0.0009	<8.09 <0.0009	Gypsum - 1 Structure
11S-27 8943 -27	3600.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 2 Structures, Gypsum - 1 Structure
11S-28 8943 -28	3600.00	0.1236	4	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 4 Structures
10N-29 8943 -29	3670.00	0.1236	0	None Detected	0 0	0.0008	<8.09 <0.0008	
10N-30 8943 -30	3660.00	0.1236	2	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 1 Structures, Gypsum - 1 Structure
10N-31 8943 -31	3630.00	0.1236	2	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 2 Structure
10N-32 8943 -32	3640.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 2 Structures, Glass - 1 Structure
10N-33 8943 -33	3630.00	0.1236	3	None Detected	0 0	0.0009	<8.09 <0.0009	Cellulose - 3 Structures
10S-34 8943 -34	3690.00	0.1236	0	None Detected	0 0	0.0008	<8.09 <0.0008	

MARK PEYSKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/etc. which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/etc. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NYLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NYLAP PL MTFM #101167-0, NY State ELAP #10879

Page 4 of 6

CITY_21MC100_009369440

10/11/2002 16:39 FAX 212 353 8308

ATC

0006

Attn: Benjamin Sallami
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22P06-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 2.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mar)	Notes
10S-35 8943-35	3680.00	0.1236	3	None Detected	0	0.0008	<8.09	Cellulose - 1 Structure, Gypsum - 7 Structure
10S-36 8943-36	3670.00	0.1236	3	None Detected	0	0.0008	<8.09	Cellulose - 3 Structures
10S-37 8943-37	3660.00	0.1236	0	None Detected	0	0.0009	<8.09	<0.0009
10S-38 8943-38	3650.00	0.1236	0	None Detected	0	0.0009	<8.09	<0.0009
A-39 8943-39	3680.00	0.1236	1	None Detected	0	0.0008	<8.09	Cellulose - 1 Structure
A-40 8943-40	3660.00	0.1236	0	None Detected	0	0.0009	<8.09	<0.0009
A-41 8943-41	3650.00	0.1236	2	CHRYSTOLE (1)	0	0.0009	8.09	Cellulose - 2 Structures
A-42 8943-42	3640.00	0.1236	3	None Detected	0	0.0009	<8.09	Cellulose - 3 Structure
A-43 8943-43	3660.00	0.1236	2	None Detected	0	0.0009	<8.09	Cellulose - 2 Structures

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mar. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NPLAP or any other agency of the U.S. Government. This report relates only to the sample reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NPLAP PLM/TEM #101187.0, NY State ELAP #10879

Page 3 of 8

CITY_21MC100_009369441

10/11/2002 16:40 FAX 212 353 6306

ATC

007

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street
New York NY 10010

Received: 10/8/02 11:10:00 AM
ATC Group #: 8943
Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 6.5µ-5 µm	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	Notes
A-44 8943 -44	3610.00	0.1236	3	None Detected	0	0.0009	<8.09	Cellulose - 3 Structures
A-45 8943 -45	3620.00	0.1236	4	None Detected	0	0.0009	<8.09	Cellulose - 1 Structure, Gypsum - 3 Structure
A-46 8943 -46	3640.00	0.1236	10	None Detected	0	0.0009	<8.09	Cellulose - 10 Structures
A-47 8943 -47	3630.00	0.1236	0	None Detected	0	0.0009	<8.09	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structural use, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structural use. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10678

Page 6 of 6

CITY_21MC100_009369442