

10/11/2002 16:40 FAX 212 353 8306

ATC

008

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Benjamin Sallemi

ATC Associates Inc.

104 East 25th Street

New York

NY 10010

Fax: (212) 353-3599

Phone: (212) 353-8280

Project: DBP Clean-up ATC Project #: 22906-0002

125 Cedar Street, New York, NY

Received: 10/8/02

11:10:00 AM

ATC Group #: 8943

Analysis Date: 10/9/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy via NIOSH
Method 7402**

Sample	Volume	Non Asbestos Fibers	PCM F/cc	Asbestos Type(s)	Asbestos Fibers	Asbestos % of total	7402 Adjusted (TEM) F/cc	Notes
PH-01 8943 -1	3850.00	3	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures
PH-02 8943 -2	3840.00	3	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures
PH-03 8943 -3	3830.00	3	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures
PH-04 8943 -4	3820.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures
PH-05 8943 -5	3810.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
12N-06 8943 -6	3820.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures, Glass - 1 Structure
12N-07 8943 -7	3810.00	9	0.001	None Detected	0	0	<0.0013	Cellulose - 9 Structures

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

ATC is not responsible for data reported in this report, which is dependent on volume collected by non-laboratory personnel. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by ATC Associates Inc.
Analysis performed by ATC Associates Inc. (NY ELAP #10876).

Forty Grid Openings from each of the samples were examined for structures greater than 5µm length and widths between 0.25µ and 3µ, and having a length-to-width ratio greater than 3:1

Page 1 of 5

CITY_21MC100_009369525

10/11/2002 16:41 FAX 212 353 8306

ATC

009

Attn: Benjamin Sallerni
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy via NIOSH
 Method 7402**

Sample	Volume	Non Asbestos Fibers	PCM F/cc	Asbestos Type(s)	Asbestos Fibers	Asbestos % of total	7402 Adjusted (TFM) F/cc	Notes
12N-08 8943 -8	3800.00	3	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures
12N-09 8943 -9	3790.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures
12N-10 8943 -10	3780.00	5	0.001	None Detected	0	0	<0.0013	Cellulose - 5 Structures
12SW-11 8943 -11	3760.00	7	0.001	None Detected	0	0	<0.0013	Cellulose - 6 Structures Gypsum - 1 Structure
12SW-12 8943 -12	3750.00	1	0.001	None Detected	0	0	<0.0013	Cellulose - 1 Structures
12SW-13 8943 -13	3740.00	6	0.001	None Detected	0	0	<0.0013	Cellulose - 6 Structures
12SE-14 8943 -14	3730.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures
12SE-15 8943 -15	3720.00	1	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures, Gypsum - 1 Structure
12SE-16 8943 -16	3710.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures, Gypsum - 1 Structure
12SE-17 8943 -17	3700.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by:

ATC is not responsible for data reported in liters/cc, which is dependent on volume collected by non-laboratory personnel. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by ATC Associates Inc.

Analysis performed by ATC Associates Inc. (NY SLAP #10678).

Forty Grid Openings from each of the samples were examined for structures greater than 5µm length and width between 0.26µ and 3µ, and having a length-to-width ratio greater than 3:1.

Page 2 of 5

CITY_21MC100_009369526

10/11/2002 16:41 FAX 212 353 8308

ATC

010

Attn: Benjamin Sallem
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8280
 Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy via NIOSH
 Method 7402**

Sample	Volume	Non Asbestos Fibers	PCM F/cc	Asbestos Type(s)	Asbestos Fibers	Asbestos % of total	7402 Adjusted (TEM) F/cc	Notes
12SE-18 8043 -18	3690.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
11N-19 8043 -19	3660.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
11N-20 8043 -20	3650.00	2	0.001	CHRYBOTILE	1	33	0.0003	Cellulose - 1 Structure
11N-21 8043 -21	3640.00	1	0.001	None Detected	0	0	<0.0013	Cellulose - 1 Structure
11N-22 8043 -22	3630.00	3	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures, Gypsum - 1 Structure
11N-23 8043 -23	3620.00	6	0.001	None Detected	0	0	<0.0014	Cellulose - 6 Structures
11S-24 8043 -24	3630.00	8	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures, Gypsum - 4 Structures, Glass - 1 Structure
11S-25 8043 -25	3620.00	7	0.001	None Detected	0	0	<0.0014	Cellulose - 6 Structures, Gypsum - 1 Structure
11S-26 8043 -26	3610.00	2	0.001	None Detected	0	0	<0.0014	Cellulose - 2 Structures
11S-27 8043 -27	3600.00	2	0.001	None Detected	0	0	<0.0014	Cellulose - 2 Structures

ROMAN FBYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

ATC is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by ATC Associates Inc.

Analysis performed by ATC Associates Inc. (NY ELAP #10673).

Forty Grid Openings from each of the samples were examined for structures greater than 5µm length and width between 0.25µm and 3µm, and having a length-to-width ratio greater than 3:1

Page 3 of 3

CITY_21MC100_009369527

10/11/2002 16:42 FAX 212 353 8306

ATC

011

Attn: Benjamin Sallemi
ATC Associates Inc.
104 East 25th Street
New York NY 10010

Received: 10/8/02 11:10:00 AM
ATC Group #: 8943
Analysis Date: 10/9/02


Fax: (212) 353-3599 Phone: (212) 353-8280

Project: DEP Clean-up ATC Project #: 22906-0002
125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy via NIOSH
Method 7402**

Sample	Volume	Non Asbestos Fibers	PCM F/cc	Asbestos Type(s)	Asbestos Fibers	Asbestos % of total	7402 Adjusted (TEM) F/cc	Notes
11S-28 8943 -28	3600.00	6	0.001	None Detected	0	0	<0.0014	Cellulose - 6 Structures
10N-29 8943 -29	3670.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
10N-30 8943 -30	3660.00	3	0.001	None Detected	0	0	<0.0013	Cellulose - 3 Structures
10N-31 8943 -31	3650.00	1	0.001	None Detected	0	0	<0.0013	Cellulose - 1 Structure
10N-32 8943 -32	3640.00	5	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures, Glass - 1 Structure
10N-33 8943 -33	3630.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures
10S-34 8943 -34	3690.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
10S-35 8943 -35	3680.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
10S-36 8943 -36	3670.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures
10S-37 8943 -37	3660.00	4	0.001	None Detected	0	0	<0.0013	Cellulose - 4 Structures

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: _____

ATC is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by ATC Associates Inc.
Analysis performed by ATC Associates Inc. (NY ELAP #10879).
Forty Grid Openings from each of the samples were examined for structures greater than 5µm length and width between 0.25µ and 3µ, and having a length-to-width ratio greater than 3:1.

Page 4 of 5

CITY_21MC100_009369528

10/11/2002 16:42 FAX 212 353 8306

ATC

012

Attn: Benjamin Sallami
 ATC Associates Inc.
 104 East 25th Street
 New York NY 10010

Received: 10/8/02 11:10:00 AM
 ATC Group #: 8943
 Analysis Date: 10/9/02

Fax: (212) 353-3599 Phone: (212) 353-8260
 Project: DEP Clean-up ATC Project #: 22906-0002
 125 Cedar Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy via NIOSH
 Method 7402**

Sample	Volume	Non Asbestos Fibers	PCM F/cc	Asbestos Type(s)	Asbestos Fibers	Asbestos % of total	7402 Adjusted (TEM) F/cc	Notes
10S-38 8943 -38	3650.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
A-39 8943 -39	3680.00	5	0.002	None Detected	0	0	<0.0013	Cellulose - 6 Structures
A-40 8943 -40	3660.00	2	0.001	None Detected	0	0	<0.0013	Cellulose - 2 Structures
A-41 8943 -41	3650.00	4	0.002	None Detected	0	0	<0.0013	Cellulose - 2 Structures, Glass - 1 Structure
A-42 8943 -42	3640.00	1	0.001	None Detected	0	0	<0.0013	Cellulose - 1 Structure
A-43 8943 -43	3660.00	8	0.001	None Detected	0	0	<0.0013	Cellulose - 8 Structures
A-44 8943 -44	3610.00	8	0.003	None Detected	0	0	<0.0014	Cellulose - 8 Structures
A-45 8943 -45	3620.00	2	0.001	None Detected	0	0	<0.0014	Cellulose - 2 Structures
A-46 8943 -46	3640.00	9	0.003	None Detected	0	0	<0.0013	Cellulose - 8 Structures, Glass - 1 Structure
A-47 8943 -47	3650.00	7	0.002	AMOSITE	1	13	0.0003	Cellulose - 7 Structures

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

ATC is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. The above report relates only to the items tested. This report may not be reproduced, except in full, without written approval by ATC Associates Inc.
 Analysis performed by ATC Associates Inc. (NY ELAP #10879)

Forty Grid Openings from each of the samples were examined for structures greater than 5µm length and widths between 0.25µ and 3µ, and having a length-to-width ratio greater than 3:1

Page 5 of 5

CITY_21MC100_009369529