



RJ Lee Group, Inc.

350 Hochberg Road, Monroeville, PA 15146

Tel: (724) 325-1776 | Fax: (724) 733-1799

Preliminary Laboratory Report

TEM Air Analysis

Mr. Chris Colbourne
Masterworks Development Corporation
56 West 45th Street
4th Floor
New York, NY 10036

Report Date: 5/3/2008
Sample Receipt Date: 5/3/2008
RJ Lee Group Job No.: TLN704891-676
Samples Received: 6
Building: 130 Cedar Street
Sampling Event: Phase IIIK Clearance

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Sample Collection		Floor-Sub Location-Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures		Concentration Analytical Sensitivity	
		Start Date-Time	End Date-Time					Chry	Amph	(S/mmf ²)	(S/cc)
5277453.HT	Area	5/2/2008 - 09:52:00		(1) - SouthWest - Location 1	385	1316	0.14765	0	0	< 6.8	< 0.002
		5/2/2008 - 13:00:00								6.8	0.002
5277454.HT	Area	5/2/2008 - 09:52:00		(1) - SouthWest - Location 2	385	1316	0.14765	0	0	< 6.8	< 0.002
		5/2/2008 - 13:00:00								6.8	0.002
5277455.HT	Area	5/2/2008 - 09:52:00		(sub level) - SouthWest - Location 3	385	1292.5	0.15633	0	0	< 6.4	< 0.002
		5/2/2008 - 13:00:00								6.4	0.002
5277456.HT	Area	5/2/2008 - 09:52:00		(Basement) - SouthWest - Location 4	385	1316	0.14765	0	0	< 6.8	< 0.002
		5/2/2008 - 13:00:00								6.8	0.002
5277457.HT	Area	5/2/2008 - 09:52:00		(Basement) - SouthWest - Location 5	385	1316	0.14765	0	0	< 6.8	< 0.002
		5/2/2008 - 13:00:00								6.8	0.002
5277458.HT	Field Blank	5/2/2008 - 09:52:00		(Basement) - SouthWest - Location 5	385	0	0.08685	0	0	< 11.5	N/A
		5/2/2008 - 09:52:00								11.5	N/A

Notes:

- Volumes provided by RJ Lee Group, Inc. were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "----" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our: Monroeville, PA (AIHA #100364, NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

DISCLAIMER

Caution must be applied when interpreting the results of samples prepared using indirect sample preparation techniques. Studies have shown that indirect preparation techniques may result in substantial increases in the fiber count when compared to fiber counts which would have been obtained using direct sample preparation.

RJ Lee Group, Inc. is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for select test methods for airborne asbestos analysis (TEM), asbestos fiber analysis (PLM), New York Department of HEALTH Environmental Laboratory Program (ELAP), and by the American Industrial Hygiene Association (AIHA). This test report relates only to the items tested. This report may not be used to claim product endorsement by NVLAP, any agency of the US Government, or any other laboratory accrediting agency. Any reproduction of this document must be in full in order for the report to be valid. This report is not valid unless it bears the name of a NVLAP-approved signatory.

These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limiting provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of ninety (90) days before discarding. A shipping and handling fee will be assessed for the return of any sample.