



THE CITY OF NEW YORK DEPARTMENT OF ENVIRONMENTAL PROTECTION
JOEL A. MIELE, SR., P.E. Commissioner

ROBERT C. AVALTRONI
Deputy Commissioner

PHONE (718) 595-4418
FAX (718) 595-4422

ASBESTOS ANALYTICAL REPORT

ASBESTOS CONTROL PROGRAM LABORATORY
96-05 HORACE HARDING EXPRESSWAY
CORONA, NEW YORK 11368
(718) 595-6309 FAX# (718) 595-6307

Bureau of
Air, Noise, & Hazardous
Materials

ELAP # 11045

TEST METHODS: 1) 40 CFR Part 763, Subpart F, App. A
2) Polarized Light Microscopy plus Stratified Point-Counting Method
3) EPA/600/R-93/116

Incident #: SVC#185065
Inspector : R. RAMMOHAN
Premise : 80 MAIDEN LANE
Boro : Manhattan
Analyst : G. FRUCHTMAN

Date Collected: 07/10/00
Received: 07/10/00
Analyzed: 07/11/00

Client #:

DEP Sample #: 00710/A078001 00710/A078002

Laboratory #: 00710/456 00710/457

Location Sampled: 12TH FLOOR 12TH FLOOR

Color: TAN TAN

Homogenous: Yes Yes

Asbestos Present: No No

Results (%)

Calcites	64	Calcites	68
Silicates	8	Silicates	16
Organic	28	Organic	16

Comments: 1. Sample #001 & 002 were ashed & acid washed.

2. Results for 001 & 002 were inconclusive for asbestos fibers.

Reviewed by: *[Signature]*
Laboratory Director

This test report may not be reproduced except with the written approval of this laboratory. The test report relates only to the item(s) listed and does not represent a product endorsement by NVLAP or any other U.S. Government agency.

59-17 Junction Boulevard, 11th Floor, Corona, New York 11368-5107



CITY_DEP_WORBY_CANNATA_SUBP_000131459